

WECC Data Preparation Manual

for Interconnection-wide Cases

Applicable to the 2018 Base Case Compilation Schedule

System Data Work Group
Data Subcommittee



155 North 400 West, Suite 200

Salt Lake City, Utah 84103-1114

Table of Contents

I. Introduction	1
II. Definitions.....	1
III. General Data Requirements and Reporting Procedures.....	2
Data Requirements	2
Reporting Procedures	3
IV. Steady-State Data Requirements.....	3
AC and DC Buses	4
Generation	6
AC Transmission Lines.....	12
Connectors	15
Transformers.....	16
Fixed Shunt Reactive Elements.....	21
Controlled Shunt Reactive Devices.....	22
Loads	25
DC Transmission Lines.....	27
Area Interchange Schedules	27
Master Tie-Line File.....	28
AC Substations	29
V. Dynamic Data Requirements	30
Generation Requirements	31
Load Requirements.....	31
Underfrequency Load Shedding (UFLS)	32
Undervoltage Load Shedding (UVLS)	32
Relays	32
Back-to-Back DC Ties.....	32
DC Lines, SVC and D-VAR systems	33

- VI. Remedial Action Scheme and Assciated Contingency Data 33**
- Appendix 1 – Late Data Procedure 35**
 - Data Submitter and Staff Responsibilities 35
 - Actions to Take..... 36
 - Backfitting of Late Data..... 36
- Appendix 2 – Area, Zone and Bus Number Assignments..... 37**
 - Southwest Region 37
 - Southern California Region 38
 - Northern California Region 39
 - Northwest Region 40
 - Canadian Region 41
 - Central Region..... 41
 - Eastern Region 42
 - Temporary Assignment..... 42
 - Miscellaneous Assignment 43

I. Introduction

The WECC Data Preparation Manual (DPM) is intended to provide an outline of data requirements and reporting procedures necessary for Data Submitters to support creation of Interconnection-wide cases for power flow and dynamic data.

Interconnection-wide cases are used to perform near-term and long-term Transmission Planning studies like seasonal Operating Transfer Capability (OTC) studies, WECC path rating studies, and regional- and local-area studies etc. Following the data requirement and reporting procedures, as outlined in the DPM, will help WECC meet the needs with the creation of Interconnection-wide cases. .

This DPM may be used by WECC members and any other entities owning/operating facilities in the Western Interconnection. The System Data Work Group (SDWG), which reports to the Data Subcommittee (DS), is responsible for maintaining the DPM with oversight from the DS and other Reliability Assessment Committee (RAC) Subcommittees. Data Submitters are responsible for making data and models available to WECC that accurately represent facilities for which they have been designated as the Data Submitter. WECC staff is responsible for collecting, archiving, modeling, and making available solved Interconnection-wide cases for use by WECC members and others that have met the WECC data security requirements.

Navigating the electronic version of the DPM:

Internal document hyperlinks: Throughout this DPM, there are many references to *internal* supporting information. These internal hyperlinks are configured such that when you see a reference that begins with “See” or “Refer to” followed by text enclosed with double quotes. Mouse over that text and you will be given the option of following the link to the supporting section of this document.

II. Definitions

Area: An Area is a subset of the Western Interconnection-wide case composed of generators and connected contiguous elements to assist in the coordinated development of a WECC Interconnection-wide case. The areas are defined by the SDWG and listed in “[Appendix 2 – Area, Zone and Bus Number Assignments.](#)”

Balancing Coordinator: Balancing Coordinator (not a NERC functional entity) is a Data Submitter who submits interchange schedules between Areas in coordination with adjacent Balancing Coordinators.

Data Submitter: Data Submitter (not a NERC functional entity) refers to a responsible entity that provides the data detailed in the DPM to support the creation of Interconnection-wide cases.

Generation Netting: The representation of a generator(s) through the modeling of a load element with the real and reactive power requirements set to the net of generation and load. Alternatively, Generation Netting may be the representation of a generator(s) using a load element with a negative Real Power demand setting. Generation Netting may be used only in Dynamic simulations by including the Generator element in the Netting section of the Positive Sequence Load Flow (PSLF) 'dyd' file for a given WECC Base Case.

Interconnection-wide Case(s): Models representing the entire Western Interconnection, which may include WECC Base Cases.

Master Dynamics File (MDF): File in PSLF 'dyd' format containing dynamic data for use in the compilation of all WECC Base Cases.

Master Tie-Line File: File in PSLF 'epc' format containing Steady-State data used to model elements of the existing Western Interconnection that represent the tie-lines between Areas and other modeling data that pertains to multiple Areas.

Planned Facilities: Facilities that have not yet met their in-service date at the time data is submitted for inclusion in a base case. See the [“General Data Requirements and Reporting Procedures”](#) section.

PSLF: General Electric's Positive Sequence Load Flow software tool for electrical transmission analysis.

PSS®E: Siemens PTI's Power System Simulator for Engineering software tool for electrical transmission analysis.

WECC Base Case(s): A set of solved and solvable steady-state and dynamic data representing a specific operating scenario of the Western Interconnection compiled by WECC staff, using the models and data provided by the data submitters.

WECC Staff: Employees of WECC who participate in the modeling and coordination of steady-state and dynamic data for use in creating WECC Interconnection-wide cases.

III. General Data Requirements and Reporting Procedures

The data requirements and reporting procedures included in this Data Preparation Manual are intended to provide an outline for Data Submitters to support creation of Interconnection-wide cases. Data Submitters should develop processes to obtain and compile the requested data.

Data Requirements

Data format and content requirements for the development of Interconnection-wide cases is broken into two data types: steady state and dynamics. Sections IV and V address each data type respectively. An additional data requirements section is provided to address the modeling of contingencies and remedial action schemes.

In consideration of including Planned Facilities in submitted data, the following guidelines should be followed:

- the facilities are expected to be in-service on the scheduled base case posting date;
- the facilities are expected to be in-service in the month and year represented in the case; or
- the facilities are required to support proposed generation facilities that are modeled in-service in the case.

All data must be the best available data.

Generator dynamic data resulting from equipment testing should be provided if it is available. If test data is not available, design data should be provided. If design data is not available, generic Dynamic data should be provided. In-service equipment should be supported by test data while far-term planned equipment may only have generic Dynamic data available.

Reporting Procedures

The schedule for Data Submitters to follow is specified in the request for data submission from WECC staff. A preliminary schedule for providing data for Interconnection-wide case creation is also included in the Base Case Compilation Schedule.

IV. Steady-State Data Requirements

To provide consistency in data submittals and help avoid potential solution problems, the guidelines below should be followed to the maximum extent possible. However, WECC recognizes deviations from the guidelines may occasionally be needed. For these situations, Data Submitters are requested to provide the SDWG and Modeling and Validation Work Group (MVWG) with the rationale for exceptions. The Interconnection-wide base cases include the following steady-state data requirements:

- With the exception of collector-based generation such as wind and solar, all Bulk Electric System (BES) elements, as presently defined by NERC, within the Western Interconnection shall be represented in WECC Base Cases without equivalencing.
- Non-Bulk Electric System elements may also be included in WECC Base Cases and follow the data submittal requirements in this DPM. Any equivalencing of non-Bulk Electric System elements shall be modeled to yield almost identical performance of a full representation in both steady state and dynamic analysis.
- Non-Bulk Electric System elements shall be included if they have significant interaction with BES elements. Non-Bulk Electric System elements that may have a significant interaction with BES elements may exhibit any of the following characteristics:
 - Facilities that are operated at or above 50 kV

- Facilities that are operated in parallel with BES elements
- Facilities with connected individual generation resources ≥ 10 MVA or aggregate generation resources ≥ 20 MVA
- Facilities with connected reactive resources ≥ 10 MVAR
- Non-Bulk Electric System Local Networks and Radial Systems that feed only load or parallel/looped systems that are normally operated in a radial configuration could generally be excluded from modeling.
- Steady-state power flow data submitted to WECC shall represent the existing Bulk Electric System elements plus planned transmission and generation facilities as described elsewhere in this document and as deemed appropriate by the Data Submitter.
- Paths defined in the WECC Path Rating Catalog shall be modeled to include all elements consistent with the path definition.
- Data fields that are strings shall not contain commas, single quotes, double quotes, or apostrophes.
- Key element identifiers (e.g., number, name, base voltage, ID) that indicate an element representing the same equipment shall be consistent between base cases.
 - Devices with alpha characters shall consistently use either uppercase or lowercase IDs.
 - Bus names with alpha characters shall consistently be either uppercase or lowercase.
- Uniqueness shall not depend on names and IDs being case sensitive.
- The requested data is listed below in the tables of data requirements. Data fields listed in this DPM are requested and any description provided for the field shall be followed.
- Bus naming guideline: Although the criterion for bus names is that ‘Bus names shall be unique within the same Base Voltage class,’ it is intended that, ideally, bus names should be the same for all equipment located in the same vicinity. For example, two substations that are in different Areas could both be named “Midway.” Names could be set to “MIDWAY” at one location, and to “MDWAY” at the other. The SDWG strongly suggests that naming of new buses added to the model adhere to the ideal guideline. It recommends, but it is not mandatory, to eliminate spaces in bus names and substitute underscore characters instead. It is the responsibility of the Data Submitter adding bus information to assure there is no name duplication.

AC and DC Buses

General Requirements:

1. Buses usually represent all of the equipment in a substation that is at the same voltage level and is connected together. If desired, multiple bus sections within a substation can be represented by separate buses connected by Connectors or AC Transmission Line models that can be opened or closed as needed. Buses may also represent a node on a transmission line such as a tapping point or change in ownership.
2. Location of the bus will be identified by the combination of Area, Zone, and/or Owner fields. Optionally, the latitude and longitude fields can be submitted using decimal degrees with data entered not to exceed five decimal places.

Table 1: Data Requirements (Buses)


Field	Description	Requirements
Number	Bus number	B1. Refer to “Appendix 2 – Area, Zone and Bus Number Assignments” for designated ranges of Bus numbers. B2. WECC staff shall provide DC Bus numbers.
Name	Bus name <ul style="list-style-type: none"> • Alphanumeric string containing 1 to 12 characters • At least one non-numeric character 	B3. Bus names shall be unique within the same Base Voltage class.
Base Voltage	Nominal voltage class of Bus (kV)	
Bus Type	AC Bus type {0,1,2,-2} <ul style="list-style-type: none"> • 0 = swing bus (voltage magnitude and phase fixed) • 1 = load bus (unconstrained voltage angle and magnitude) • 2 = generator bus (voltage control [terminal or remote] within generator limits) • -2 = generator bus with unlimited reactive power limits Other bus types may be used to indicate OFF status. Bus type -4 and smaller is the accepted convention for deleted buses. DC Bus type {1,2} <ul style="list-style-type: none"> • 1 = for a rectifier • 2 = for an inverter 	

Field	Description	Requirements
DC System Number	DC system number (not required for AC Bus)	B4. WECC staff shall assign a DC system number for each DC system prior to model submission.
Scheduled Voltage	Scheduled voltage (pu) <ul style="list-style-type: none"> • 5 decimals • Default: 1.00000 	B5. If the Bus is regulated by a generator or other device, the scheduled voltage shall be specified in per unit with respect to the Base Voltage of the Bus. B6. If the Bus is not regulated, the scheduled voltage is optional and for information purposes only.
Area	Area in which Bus is located	B7. Refer to “Appendix 2 – Area, Zone and Bus Number Assignments” for designated Area.
Zone	Zone in which Bus is located	B8. Refer to “Appendix 2 – Area, Zone and Bus Number Assignments” for designated ranges of Zones used by Area.
Owner	Owner Number	B9. Owner Number shall be the Transmission Owner, Generator Owner, or Data Submitter, by written agreement. B10. WECC staff shall assign Owner Number to required entities.
Substation	Substation in which Bus is assigned	B11. Buses relative to GIC analysis shall be assigned to a substation
Balancing Authority	Balancing Authority in which Bus is located	B12. All buses shall be assigned to a Balancing Authority

Generation

- Generators selected for Area Slack Control, including the system slack, shall meet the same technical requirements as selecting generators for automatic generation control (AGC) of a Balancing Authority area. Generators selected for AGC typically have the following attributes:
 - Change in MW output causes small change in generator angle (suggested; $d\text{Angle}/dP < 0.15$ degrees/MW).
 - Generation is dispatchable.
 - Maximum MW output typically greater than 100 MW.
 - Unit is expected to be in service for time period represented in the WECC base case.
- Modeling of generators shall comply with the following:

- a. If the individual generator unit capacity is 10 MVA or larger and is connected to the WECC transmission system at 60 kV or higher, then steady-state data and dynamics data should be submitted for each generator.
 - b. If the aggregated generator unit capacity is 20 MVA or larger, is connected to the WECC transmission system at 60 kV or higher and is not a collector-based generation facility, then steady-state data and dynamics data should be submitted for each generator. (Wind and solar farms are examples of collector-based generation facilities.)
 - c. If the aggregated generation capacity is 20 MVA or larger, is connected to the WECC transmission system at 60 kV or higher and is a collector-based generation facility, then steady-state data and dynamics data should be submitted for the aggregated generation capacity as a single-unit generator model. (Wind and solar farms are examples of collector-based generation facilities.)
 - d. All other generating facilities shall be netted with bus load in steady-state data and have their non-conforming load Flag set appropriately. Steady-state and dynamic generator data shall be consistent.
3. Synchronous motors 10 MVA and larger shall be modeled as individual machines, using a generator model with negative Real Power output and constant Reactive Power (Q) output.
 4. Induction motors shall be modeled as a load with the intent of using an induction motor model (MOTORW).
 5. Synchronous condensers shall be modeled individually using a generator model.
 6. Generator step-up transformers shall be modeled explicitly; therefore, they shall not be modeled using the internal generator step-up transformer feature of a generator model. All related parameters shall be set to the default values. See [“Data Requirements \(Transformers\).”](#)
 7. Station service loads (ID = ‘SS’) shall be represented explicitly as separate loads on the generator bus. See [“Data Requirements \(Loads\).”](#)
 8. Wind and photovoltaic plants shall be represented through an equivalent generator(s), equivalent low-voltage to intermediate-voltage transformer, equivalent collector system, and substation transformer between the collector system and the transmission bus. See the [WECC Wind Power Plant Power Flow Modeling Guide](#) and [PV Plant Power Flow Modeling Guide](#).



9. Large industrial sites may include imbedded generation. Industrial aggregated generation capacity of 10 MVA and larger shall be represented in power flow instead of netting with the total load. If a generator is connected to the low side of the bulk-power-delivery transformer, then the transformer must be represented in the power flow and the generator and load must be connected to the low-voltage side of the transformer.
10. Generator maximum Real Power Pmax in power flow must be consistent with the turbine capabilities defined in the Master Dynamics File.

Table 2: Data Requirements (Generation)

Field	Description	Requirements	Measure
Bus Numbers	Number of the Bus to which the generator is attached. <ul style="list-style-type: none"> • See “Data Requirements (Buses)” 		
Unit ID	Two -character Generator identifier		
Status	Generator status <ul style="list-style-type: none"> • 1 = in-service • 0 = out-of-service 	G1. Out-of-service units shall have status set to zero. G2. Retired units shall be deleted rather than having status set to zero.	
Pgen	Real Power output (gross MW)	G3. Pgen shall be at or within the unit Pmax and Pmin parameters for units that are in-service.	If Status = 1: Pmin ≤ Pgen ≤ Pmax
Qgen	Reactive power output (MVA _r)		

Field	Description	Requirements	Measure
Pmax	Maximum Real Power output (MW)	<p>G4. Pmax shall reflect the maximum Real Power output of the unit, also known as ‘gross’ capability.</p> <p>G5. Pmax shall not be greater than the maximum capability of the unit represented by the governor model.</p>	$P_{max} \leq \text{Governor Max}$
Pmin	Minimum Real Power output (MW)	<p>G6. Pmin shall reflect the minimum Real Power output of the unit.</p> <p>G7. Pmin shall be less than or equal to Pmax.</p>	$P_{min} \leq P_{max}$
Qmax	Maximum reactive power output (MVar)	G8. Qmax shall reflect the appropriate maximum reactive power output of the unit.	
Qmin	Minimum reactive power output (MVar)	<p>G9. Qmin shall reflect the appropriate minimum reactive power output of the unit.</p> <p>G10. Qmin shall be less than or equal to Qmax.</p>	$Q_{min} \leq Q_{max}$
Q Alloc Factor	<p>Reactive power regulating assignment factor</p> <ul style="list-style-type: none"> • 0.0 – 1.0 • > 0.0 for AVR control • 0.0 for constant PF control or gen Status=0 		
Q Table Flag	<p>Reactive capability curve flag</p> <ul style="list-style-type: none"> • 0 = do not use capability curve • 1 = use capability curve if it exists 	<p>G11. Q-Table data used for internal studies shall be included in WECC Base Case submittals.</p> <p>G12. PMax value shall exist on the Q Table if used.</p>	

Field	Description	Requirements	Measure
Base load Flag	Base load flag <ul style="list-style-type: none"> • 0 = non-base load unit (responds to low frequency with additional mechanical power) • 1 = base load unit (cannot respond to low frequency with additional mechanical power) • 2 = base load unit (cannot respond to low and high frequency with mechanical power) 	G13. Base Load Flag Shall be consistent between steady-state and dynamics models	
Turbine Type	<ul style="list-style-type: none"> • 0 = unknown • 1 = steam turbine (except steam of combined cycle) • 2 = combined cycle steam part • 3 = steam cross-compound • 4 = combined cycle total unit (planned gens and details for separate model not available) • 5 = hydro • 6 = Internal Combustion Engine (diesel, piston, reciprocating) • 7 = diesel turbo charged • 11 = GT (single shaft, does not include turbine part) • 12 = aero derivative GT • 13 = single-shaft combined cycle • 14 = Synchronous condenser (no turbine) • 19 = Turbines used in a Binary Cycle (including geothermal) • 20 = type unknown wind turbine • 21 = type 1 wind turbine (onshore only) • 22 = type 2 wind turbine(onshore only) • 23 = type 3 wind turbine(onshore only) • 24 = type 4 wind turbine (onshore only) 		

Field	Description	Requirements	Measure
	<ul style="list-style-type: none"> • 25 = wind turbine (offshore) • 29 = combined cycle combustion turbine part • 31 = photovoltaic • 40 = DC tie (generators representing DC ties) • 41 = motor/pump • 42 = energy storage -battery • 43 = energy storage - flywheel • 44 = energy storage – other • 46 = energy storage – compressed air • 47 = energy storage – concentrated solar power • 51 = hydrokinetic, axial flow turbine • 52 = hydrokinetic – wave buoy • 53 = hydrokinetic - other • 54 = energy storage – reversible hydraulic turbine • 99 = other 		
Reg Bus	Bus with voltage controlled by this generator	G14. Regulation of a remote Bus that does not represent actual system operation shall be avoided.	
Vsched	Generator scheduled voltage (pu)		
Area	Area in which generator is located	G15. Refer to “Appendix 2 – Area, Zone and Bus Number Assignments” for designated Area.	
Zone	Zone in which generator is located	G16. Refer to “Appendix 2 – Area, Zone and Bus Number Assignments” for designated ranges of Zones used by Area	
Base MVA	Generator base (MVA)	G17. Unit Base MVA shall be equal to the MVA Base parameter of the unit’s Dynamic machine model.	Base MVA = Machine Base
Owner	Owner Number <ul style="list-style-type: none"> • Up to eight owners allowed 	G18. Owner Number shall be the Generator Owner. G19. WECC staff shall assign Owner Number to required entities.	

Field	Description	Requirements	Measure
G tap	Tap ratio of generator step-up transformer	G20. G tap shall be set to 1.	G tap = 1
R TR	Resistance of generator step-up transformer	G21. R TR shall be set to 0.	R TR = 0
XTR	Reactance of generator step-up transformer	G22. X TR shall be set to 0.	X TR = 0
R Sub-transient	Sub-transient resistance of generator		
X Sub-transient	Sub-transient reactance of generator	G23. X Sub-transient shall be equal to the sub-transient reactance represented in the unit Dynamic machine model.	X Sub-transient = Xdpp (or Ldpp)
Balancing Authority	Balancing Authority Area in which Generator is located		

AC Transmission Lines

1. Series-connected reactive devices modeled in AC Transmission Lines shall be explicitly modeled.
2. AC Transmission Line models connecting two Areas, as defined by WECC, shall be maintained in the “Master Tie-Line File”.
3. When breakers are explicitly represented in the model, they should be modeled as Breakers with the Connector Type field set to Breaker (See Connector section).
4. AC transmission lines modeled with impedance below $X = 0.00029$ p.u. (the threshold impedance in PSLF) shall not be used to represent a closed loop (ring bus representation).
5. Normal and emergency thermal rating fields for the seasonal scenario described in the base case data request letter shall be populated for all AC Transmission Line models.
6. Line-connected transformers shall not be modeled using the internal line-connected transformer feature of a transmission line model; all related parameters shall be set to the default values. See “Data Requirements (Transformers).”
7. Data for AC lines will consider the length of the line when calculating line parameters. For example, long lines will be modeled with impedances adjusted to account for the uniform distribution of the series impedance and shunt admittance along the length of the line.
8. PSS®E base case data includes three facility ratings for transmission lines. Ratings 1 and 2 are used for seasonal normal and emergency ratings corresponding to the season of the case. Rating 3 is

used for various other purposes. If directed, WECC staff will move ratings 1 and 2 into the appropriate seasonal ratings columns for the PSLF version of the base case being developed.

Table 3: Data Requirements (AC Transmission)

Field	Description	Requirements	Measure
FROM Bus Number	Number of the bus to which the FROM end of the transmission line section is attached. • See “Data Requirements (Buses)”		
TO Bus Number	Number of the bus to which the TO end of the transmission line section is attached. • See “Data Requirements (Buses)”		
Circuit ID	Circuit identifier • Two-character circuit identifier	X1. AC Transmission Line modeling equivalent circuits shall have Circuit ID set to ‘99’ or ‘EQ.’	
Section Number	Section number (1-9 in ascending order beginning at FROM end)	X2. AC Transmission Line with multiple sections shall number the sections consecutively starting with ‘1.’	
Status	Branch status • 0 = out-of-service • 1 = in-service • 2 = bypass	X3. AC Transmission Line shall have the anticipated status of the line in the case.	
R	Branch section positive sequence resistance	X4. Resistance used for modeling an AC Transmission Line shall conform to the modeling practices as deemed appropriate by the Data Submitter.	
X	Branch section positive sequence reactance	X5. Reactance used for modeling an AC Transmission Line shall conform to the modeling practices as deemed appropriate by the Data Submitter.	
B	Branch section positive sequence susceptance	X6. Susceptance used for modeling an AC Transmission Line shall conform to the modeling practices as deemed appropriate by the Data Submitter.	
Rating MVA 1	Summer Normal Branch Rating (MVA)	X7. Line rating required	Rating MVA 1 > 0

Field	Description	Requirements	Measure
Rating MVA 2	Summer Emergency Branch Rating (MVA)	X8. Line rating required	Rating MVA 2 > 0
Rating MVA 3	Winter Normal Branch Rating (MVA)		
Rating MVA 4	Winter Emergency Branch Rating (MVA)		
Rating MVA 5	Fall Normal Branch Rating (MVA)		
Rating MVA 6	Fall Emergency Branch Rating (MVA)		
Rating MVA 7	Spring Normal Branch Rating (MVA)		
Rating MVA 8	Spring Emergency Branch Rating (MVA)		
From Loss Assign.	Loss factor (0.0 - 1.0) used to assign losses <ul style="list-style-type: none"> • 1.0 = 100% loss assigned to FROM end of AC Transmission Line • 0.0 = 100% loss assigned to "TO" end of AC Transmission Line 		
Area	AC Transmission Line Area location	X9. Refer to " Appendix 2 – Area, Zone and Bus Number Assignments " for designated Area	
Zone	Transmission Line Zone location	X10. Refer to " Appendix 2 – Area, Zone and Bus Number Assignments " for designated ranges of Zones used by area	
Ohms	Ohmic data flag <ul style="list-style-type: none"> • 0 = impedances in pu • 1 = impedances in ohms 		
Owner	Owner Number (1 through 8)	X11. Owner Number shall be the Transmission Owner of transmission facility and Generator Owner for lines within generation facility. X12. WECC staff shall assign Owner Number to required entities.	

Connectors

1. For the purpose of this DPM, Connectors should be considered as objects other than transmission lines, series capacitor, series reactors and transformers connecting two buses. Breakers can be modeled as Connectors.
2. MVA or Amp Ratings for Connectors are not required. The connected transmission line or transformer may include the connector rating if the connector is the most limiting element of the devices intended to be represented in the model.

Table 4: Data Requirements (Connector)

Field	Description	Requirements	Measure
FROM Bus Number	Number of the bus to which the FROM end of the Connector is attached. • See “Data Requirements (Buses)”		
TO Bus Number	Number of the bus to which the TO end of the Connector is attached. • See “Data Requirements (Buses)”		
ID	Connector identifier • Two-character identifier		
Status	Connector status • 0 = out-of-service • 1 = in-service • 2 = bypass	B1. Connector shall have the anticipated status of the line in the case.	
Connector Type	Connector device type • Breaker • Load break disconnect • Disconnect • Fuse • Ground disconnect		
Allow Consolidation	Flag for allowing topology processing to consolidate the Connector within a “superbus” • YES • NO		

Field	Description	Requirements	Measure
Rating MVA 1	Summer Normal Connector Rating (MVA)		
Rating MVA 2	Summer Emergency Connector Rating (MVA)		
Rating MVA 3	Winter Normal Connector Rating (MVA)		
Rating MVA 4	Winter Emergency Connector Rating (MVA)		
Rating MVA 5	Fall Normal Branch Connector (MVA)		
Rating MVA 6	Fall Emergency Connector Rating (MVA)		
Rating MVA 7	Spring Normal Connector Rating (MVA)		
Rating MVA 8	Spring Emergency Connector Rating (MVA)		

Transformers

General Requirements

1. Transformers with no Tap Changing Under Load (TCUL) or phase-shifting capability shall have the Tap Control Type field set to '1' and shall not have TCUL or phase-shifting data included in the cases. Conversion from the latest approved version of PSLF to other widely used programs may create model discrepancies with partial TCUL or phase-shifting data. Actual transformer equipment type shall be represented.
2. Transformer data can be entered on either the transformer base (transformer winding MVA base and winding voltage base) or the system model base (100 MVA and system nominal voltage base). Impedance values and tap position values shall use a consistent unit base value for a given transformer.
3. Transformer models connecting two Areas, as defined by WECC, shall be represented in the Master Tie-Line File (see "[Appendix 2 – Area, Zone, and Bus Number Assignments](#)" for designated Areas").
4. Normal and Emergency thermal rating fields corresponding to the seasonal scenario described in the base case data request letter shall be populated for all Transformer models.
5. The Transformer Impedance Correction Table shall be maintained in the "Master Tie-Line File."

6. PSS®E cases use ratings 1 and 2 for seasonal normal and emergency ratings corresponding to the season of the case. If directed, WECC staff will move ratings 1 and 2 into the appropriate seasonal ratings columns for the PSLF version of the Base Case being developed.

Table 5: Data Requirements (Transformers)

Field	Description	Requirements	Measure
FROM Bus Number	Number of the bus to which the FROM end of the transformer is attached. • See “Data Requirements (Buses)”		
TO Bus Number	Number of the bus to which the “TO” end of the transformer is attached. • See “Data Requirements (Buses)”		
Circuit ID	Circuit identifier • Two-character circuit identifier	T1. Transformer modeling equivalent circuits shall have Circuit ID set to ‘99’ or ‘EQ.’	
Status	Transformer Status • 0 = out-of-service • 1 = in-service • 2 = secondary open • 3 = tertiary open • 4 = primary open	T2. Transformers shall have the anticipated status of the transformer in the case.	
Tap Control Type	Transformer type code • 1 or 11 = Fixed • 2 or 12 = TCUL • -2 or -12 = TCUL Disabled • 4 or 14 = Phase-Shifting • -4 or -14 = Phase Shifting Disabled	T3. TCUL Disabled and Phase Shifting Disabled should be used to represent a temporary physical change in transformer control or to address potential modeling issues	
Regulated Bus Number	Number of Bus with voltage regulated or “TO” bus number for phase-regulated transformers.	T4. Regulation of a remote bus that does not represent actual system operation shall be avoided.	
Impedance Table Number	Impedance correction table number.		

Field	Description	Requirements	Measure
Tert Bus Number	Tertiary winding Bus number • See “Data Requirements (Buses)”		
3wpt Bus Number	Internal ‘3-winding point’ Bus number See “Data Requirements (Buses)”	T5. This bus number shall be unique to the transformer and be consistent in all cases	
Area	Area in which Transformer is located	T6. Refer to “Appendix 2 – Area, Zone and Bus Number Assignments” for designated Area.	
Zone	Zone in which Transformer is located	T7. Refer to “Appendix 2 – Area, Zone and Bus Number Assignments” for designated ranges of Zones used by Area.	
FROM-TO Base MVA	Transformer MVA base (prim. to sec. for 3-wndg)		
FROM-Tert Base MVA	MVA base - prim. to tertiary for 3-wndg		
TO-Tert Base MVA	MVA base - tertiary. to sec. for 3-wndg		
R FROM-TO	Resistance primary to secondary		
X FROM-TO	Reactance primary to secondary		
R FROM-Tert	Resistance primary to tertiary		
X FROM-Tert	Reactance primary to tertiary		
R TO-Tert	Resistance secondary to tertiary		
X TO-Tert	Reactance secondary to tertiary		
FROM Winding Nom Volt	Primary winding nominal voltage (kV)		
TO Winding Nom Volt	Secondary winding nominal voltage (kV)		
Tert Winding Nom Volt	Tertiary winding nominal voltage (kV)		
FROM Fixed Tap	Primary winding fixed tap position (pu)		

Field	Description	Requirements	Measure
TO Fixed Tap	Secondary winding fixed tap position (pu)		
Tert Fixed Tap	Tertiary winding fixed tap position (pu)		
Variable V Tap or Variable Angle	TCUL tap position (primary winding) or phase angle position	T8. Variable V Tap or Variable Angle shall be at or within Max VAr Tap and Min VAr Tap for Transformers that are in-service.	Min VAr Tap \leq V Tap \leq Max VAr Tap
Step Size	TCUL (pu) or phase-shift (angle in deg) step	T9. Step Size shall reflect the capability of the transformer.	
FROM Angle	Primary winding phase angle (deg)		
TO Angle	Secondary winding phase angle (deg)		
Tertiary Angle	Tertiary winding phase angle (deg)		
G-Core Loss	Magnetizing conductance (pu)		
B Magnetizing	Magnetizing susceptance (pu)		
Rating 1	Summer Normal Branch Rating (MVA) (primary winding for 3-winding xfmr)	T10. Transformer rating required.	Rating MVA 1 > 0
Rating 2	Summer Emergency Branch Rating (MVA) (primary winding for 3-winding xfmr)	T11. Transformer rating required.	Rating MVA 2 > 0
Rating 3	Winter Normal Branch Rating (MVA) (primary winding for 3-winding xfmr)		
Rating 4	Winter Emergency Branch Rating (MVA) (primary winding for 3-winding xfmr)		
Rating 5	Fall Normal Branch Rating (MVA) (primary winding for 3-winding xfmr)		
Rating 6	Fall Emergency Branch Rating (MVA) (primary winding for 3-winding xfmr)		

Field	Description	Requirements	Measure
Rating 7	Spring Normal Branch Rating (MVA) (primary winding for 3-winding xfmr)		
Rating 8	Spring Emergency Branch Rating (MVA) (primary winding for 3-winding xfmr)		
TO Winding Rating MVA 1	Ratings – secondary winding for 3-winding xfmr		
TO Winding Rating MVA 2	Ratings – secondary winding for 3-winding xfmr		
TO Winding Rating MVA 3	Ratings – secondary winding for 3-winding xfmr		
Tert Wind. Rating MVA 1	Ratings – tertiary winding for 3-winding xfmr		
Tert Wind. Rating MVA 2	Ratings – tertiary winding for 3-winding xfmr		
Tert Wind. Rating MVA 3	Ratings – tertiary winding for 3-winding xfmr		
FROM Loss Assign	Loss assignment factor (primary winding for 3-winding xfmr) (pu)		
TO Loss Assign	Loss assignment factor - secondary winding for 3-winding xfmr (pu)		
Tert Loss Assign	Loss assignment factor – tertiary winding for 3-winding xfmr (pu)		
Max Var. Tap	Maximum TCUL ratio (pu or deg)	T12. Max Var. Tap shall be greater than Min Var. Tap.	
Min Var. Tap	Minimum TCUL ratio (pu or deg)		
Max Cont V or MW	Maximum voltage (power) at controlled bus (pu or MW)	T13. Max Cont V shall be greater than Min Cont V.	

Field	Description	Requirements	Measure
Min Cont V or MW	Minimum voltage (power) at controlled bus (pu or MW)		
Ohms	Ohmic data flag <ul style="list-style-type: none"> • 0 = impedances in pu • 1 = impedances in ohms 		
Owner	Owner Number (1 through 8)	T14. Owner Number shall be the Transmission Owner for transmission facility and Generator Owner for generator facility. T15. WECC staff shall assign Owner Number to required entities.	

Fixed Shunt Reactive Elements

General Requirements

1. Represent fixed shunt elements that are directly connected to a bus as bus shunts.
2. Represent fixed shunt elements that directly connect to and switch with a transmission line as line shunts.
3. Fixed Line Shunt models connected to an AC Transmission Line model connecting two Areas, as defined by WECC, shall be represented in the “Master Tie-Line File” if requested by the process detailed in the data submission request.
4. Fixed shunt reactive devices inside wind and solar projects must be modeled explicitly in power flow.

Table 6: Data Requirements (Fixed Shunts)

Field	Description	Requirement
FROM Bus Number	Number of the Bus to which the FROM end of the transmission line on which the shunt is connected for line shunts or number of the Bus at which shunt is connected for bus shunts. <ul style="list-style-type: none"> • See “Data Requirements (Buses)” 	
TO Bus Number	Number of the Bus to which the TO end of the transmission line on which the shunt is connected, for line shunts or 0 for bus shunts. <ul style="list-style-type: none"> • See “Data Requirements (Buses)” 	

Field	Description	Requirement
Shunt ID	Shunt identifier <ul style="list-style-type: none"> • Two-character shunt identifier 	F1. Line shunt connected to the FROM end of the transmission line shall have Shunt ID starting with 'F.' F2. Line shunt connected to the TO end of the transmission line shall have Shunt ID starting with 'T.'
Circuit ID	AC Transmission Line circuit identifier for line shunts or blank for bus shunts <ul style="list-style-type: none"> • Two-character circuit identifier 	
Section Number	Number of AC Transmission Line section to which shunt is connected if line shunt or '0' if bus shunt	
Shunt Status	Shunt status <ul style="list-style-type: none"> • 0 = out-of-service • 1 = in-service 	F3. Fixed shunts shall have the anticipated status of the shunt in the case.
Area	Area in which fixed shunt is located	F4. Refer to " Appendix 2 – Area, Zone and Bus Number Assignments " for designated Area.
Zone	Zone in which fixed shunt is located	F5. Refer to " Appendix 2 – Area, Zone and Bus Number Assignments " for designated ranges of Zones used by Area.
G	Actual shunt conductance (pu)	
B	Actual shunt susceptance (pu)	
Owner	Owner Number (1 – 4)	F6. Owner Number shall be the Transmission Owner or Generator Owner. F7. WECC staff shall assign Owner Number to required entities.

Controlled Shunt Reactive Devices

General Requirements

- Controlled shunt reactive device models should be used to represent the following devices explicitly in power flow:
 - Mechanically switched shunt capacitors and reactors;
 - Static VAR Compensators;
 - STATCOMs; and/or

- Thyristor-switched shunt capacitors and reactors.
2. Controlled shunt reactive devices inside wind and solar projects must be modeled explicitly in power flow.
 3. The number of explicitly modeled shunts on a bus should be minimized to aid solving.

Table 7: Data Requirements (Controlled Shunts)

Field	Description	Requirement
Bus Number	Number of Bus at which device is connected <ul style="list-style-type: none"> • See “Data Requirements (Buses)” 	
SVD ID	SVD identifier <ul style="list-style-type: none"> • Two-character identifier 	
SVD Status	SVD status <ul style="list-style-type: none"> • 0 = out-of-service • 1 = in-service 	S1. Controlled shunts shall have the anticipated status of the shunt in the case.
SVD Control Type	Device type <ul style="list-style-type: none"> • 0 = Fixed • 1 = Discrete • 2 = Continuous • 3 = All or Nothing • 4 = Discrete control using Voltage Dead Band • 5=WECC SVC • 6=WECC STATCOM • 7=WECC TSC/TSR 	
Regulated Bus	Number of Bus regulated by this shunt <ul style="list-style-type: none"> • See “Data Requirements (Buses)” 	S2. Regulation of a remote Bus that does not represent actual system operation shall be avoided.
Area	Area in which Controlled Shunt is located	S3. Refer to “Appendix 2 – Area, Zone and Bus Number Assignments” for designated Area.
Zone	Zone in which Controlled Shunt is located	S4. Refer to “Appendix 2 – Area, Zone and Bus Number Assignments” for designated ranges of Zones used by Area.
G Actual	Actual shunt conductance (pu)	
B Actual	Actual shunt susceptance (pu)	
B Min	Minimum susceptance of continuous element (pu)	
B Max	Maximum susceptance of continuous element (pu)	

Field	Description	Requirement
Voltage Dead Band	Voltage control bandwidth divided by two (pu) (types 3 and 4)	S5. Voltage Dead Band shall prevent regulated voltage from exceeding the Voltage Dead Band with a single Controlled Shunt step. S6. The minimum dead band shall be 0.02.
B Step	Susceptance of each switched element in nth stage (pu) (types 1-4, 7)	S7. Step size shall reflect the capability of the controlled shunt.
No. of Steps	Number of equal admittance steps in nth switched stage (types 1-4, 7)	S8. Number of steps shall reflect the capability of the controlled shunt.
B Min	Minimum total susceptance for device (pu)	
B Max	Maximum total susceptance for device (pu) Maximum current for type 6 (pu)	
XC	Compensating (slope) reactance (pu) (types 5, 6, 7)	
B Min SH	Minimum B for switching shunts (pu) (types 5, 6, 7)	
B Max SH	Maximum B for switching shunts (pu) (types 5, 6, 7)	
STSB	Slow reset control on/off status (pu) (types 5, 6, 7)	
B Min SB	Minimum B for slow reset (pu) (pu) (types 5, 7)	
B Max SB	Maximum B for slow reset (pu) (pu) (types 5, 7)	
VRFMIN	Minimum Voltage reference for slow reset (pu) (types 5, 6, 7) Minimum Voltage reference for types 3 and 4 if Voltage Dead Band <= 0	
VRFMAX	Maximum Voltage reference for slow reset (pu) (types 5, 6, 7) Maximum Voltage reference for types 3 and 4 if Voltage Dead Band <= 0	
dVdB	System dV/dB for slow reset (pu) (types 5, 6, and 7)	
Ni	Number of steps in shunt	
Owner	Owner Number (1 through 4)	S9. Owner Number shall be the Transmission Owner or Generator Owner. S10. WECC staff shall assign Owner Number to required entities.
Balancing Authority	Balancing Authority Area in which Shunt is located	

Loads

General Requirements

1. Real and reactive power for each load shall be provided.
2. Motors 10 MVA or larger shall be modeled as machines (see “[Generation](#)”).
3. Station service at modeled generation facilities with station service load greater than or equal to 1 MW shall be modeled explicitly. As noted in the table below, load modeling generator station service shall have Load ID set to ‘SS.’
4. A Long ID shall be provided for each load in accordance with the WECC MVWG Load-Long ID Instructions ([LID_Instructions](#)), either within the case data provided, or in a separate spreadsheet file. Data Submitter shall select an appropriate Long ID that correctly represents the Dynamic load characteristics. See “[Dynamic section Load Characteristics](#)”.
5. Industrial loads and embedded generation shall be modeled on the low side of the transformer, as shown in the figure below.




Table 8: Data Requirements (Loads)

Field	Description	Requirement
Bus Number	Number of Bus at which load is connected <ul style="list-style-type: none"> • See “Data Requirements (Buses)” 	
Load ID	Two-character identifier	L1. Load modeling generator station service shall have Load ID set to ‘SS.’ L2. Loads at the same Bus shall have unique Load ID.
Load Status	<ul style="list-style-type: none"> • 0 = load out-of-service • 1 = load in-service 	L3. Load shall have the anticipated status of the load in the case.

Field	Description	Requirement
Non-Conforming Flag	<ul style="list-style-type: none"> • 0 = load will change with scaling • 1 = load does not change with scaling 	L4. Non-conforming Flag shall be set to '1' for loads that should not be changed in load scaling operation of power flow software.
Area	Load Area in which located	L5. Refer to " Appendix 2 – Area, Zone and Bus Number Assignments " for designated Area.
Zone	Load Zone in which located	L6. Refer to " Appendix 2 – Area, Zone and Bus Number Assignments " for designated ranges of Zones used by Area.
Const MVA P	Constant MVA Real Power load	
Const MVA Q	Constant MVA reactive power load	
Const CUR P	Constant current Real Power load	L7. Const CUR P shall not be used.
Const CUR Q	Constant current reactive power load	L8. Const CUR Q shall not be used.
Const Y P	Constant admittance Real Power load	L9. Const Y P shall not be used.
Const Y Q	Constant admittance reactive power load	L10. Const Y Q shall not be used.
Owner	Owner Number	<p>L11. Owner Number shall be the Transmission Owner for transmission loads, Generator Owner for station service, Distribution Service Provider for distribution loads.</p> <p>L12. WECC staff shall assign Owner Number to required entities.</p>
Long ID	Climate zone and substation type identification	L13. Seven-character identifiers of the climate zone and load type – the first three characters represent the climate zone, followed by underscore, and three characters representing the substation/feeder load mix type. Details are included in the LID_Instructions and Composite Load Model Implementation documents.
Balancing Authority	Balancing Authority Area in which Load is located	

DC Transmission Lines

General Requirements

1. Include (at a minimum) the following DC Transmission Line (overhead and underground) requirements: line parameters, Normal and Emergency Ratings, control parameters, rectifier data, and inverter data.
2. Megawatt set-point of converter data shall be equal to or less than the DC Transmission Line Rating.

Table 9: Data Requirements (DC Transmission)

Field	Description	Requirement	Measure
ifrom	DC 'FROM' bus number		
ito	DC 'TO' bus number		
ck[2]	DC line identifier		
projid	Project Identifier		
st	DC line status		
dcsys	DC system number		
Area	Area number		
Zone	Zone number		
r	DC line resistance		Ohms
l	DC line inductance		Henries
c	DC line capacitance		microfarad
rate[8]	DC current ratings		Amps
aloss	DC line loss assignment factor		per unit
nown[8]	Owner Number		
Balancing Authority	Balancing Authority Area in which DC bus & converter are located		

Area Interchange Schedules

General Requirements

1. Area Interchange schedules shall be coordinated between Areas to meet the objectives of the data request letter and maintain consistency in the imports/exports modeled.

2. The sum of net Area Interchange Schedules for the Interconnection-wide case shall be equal to zero.
3. WECC staff shall set the Real Power Net Interchange Tolerance equal to 1.0 MW for each Area.

Master Tie-Line File

When requested by the process detailed in the data submission request the Master Tie-Line File (MTLF) contains:

- Master lists of Owners and Zones;
- Path definitions and ratings for paths in the WECC Path Rating Catalog;
- Lists of lines and transformers that interconnect Areas; and
- Placeholder for Area-to-Area transactions for the existing system.
- Master List of Balancing Authorities

General Requirements When Used to Build Interconnection-Wide Cases

1. WECC staff shall maintain the MTLF.
2. WECC staff shall post the current MTLF in the present year's base-case files on the WECC website.
3. The MTLF is used in the compilation of all base cases to ensure consistency of steady-state data common to multiple Areas.
4. Updates to the MTLF shall be coordinated between Areas and submitted to WECC staff in an 'epc' file format or excel spreadsheet format as necessary by the Data Submitter.
5. The MTLF shall be maintained and applied to all WECC base cases. The tie-line data pertaining to planning horizon cases will be handled on a case-by-case basis.

Data Requirements (Area Interchange)

1. Tie-Lines –Existing transmission lines (including line shunts) and transformers connecting two Areas shall have steady-state data submitted to WECC staff for inclusion in the MTLF (see Section “AC Transmission Lines” and “Transformers” respectively). Tie changes are not captured when only included in the case data submissions. These changes or updates must be submitted separately from typical case data submissions (or as separate files included within the case data).
2. Zones – Zone Names and Zone Numbers shall be maintained in the MTLF in accordance to the process detailed in the data submission request. Zone assignments to the WECC member systems can be found in Appendix 2 (see “Appendix 2 – Area, Zone and Bus Number Assignments.”)
3. WECC staff shall identify paths (as listed in the WECC Path Rating Catalog) in accordance to the process detailed in the data submission request. The Interface Number shall match the WECC path

number. Rating 1 shall be used for the Path Transfer Limit for prevailing flow direction and Rating 2 shall be used for the secondary flow direction Path Transfer Limit.

4. WECC path element information shall be maintained in the MTLF in accordance to the process detailed in the data submission request. Data Submitters shall provide updates to WECC staff as changes are made or as facilities are placed in-service.
5. Facility owners of DC buses, lines, and converters that are part of any area tie-line shall provide the steady-state data to be maintained in the MTLF. (See Section “DC Transmission Lines”) .
6. Transformer Impedance Correction Table – Impedance correction parameters to be used for TCUL transformers and phase-shifting transformers shall be maintained in the MTLF in accordance to the process detailed in the data submission request.
7. Owner Data – A list of Owner Numbers, names, and four-character abbreviations shall be maintained in the MTLF in accordance to the process detailed in the data submission request.
8. Transaction Data – There must be a transaction for any ties between Areas. WECC Staff manages this data in accordance to the process detailed in the data submission request on a case-by-case basis.
9. Balancing Authority – WECC staff will maintain a list of Balancing Authorities to represent the actual Balancing Authorities used in the existing operation of the transmission system.

AC Substations

General Requirements:

1. Substations represent all the buses in a substation. These collections of buses are connected by transformer and/or bus sectionalizing breakers.

Table 10: Data Requirements (AC Substations)

Field	Description	Requirement
Sub Number	Substation Number	Each substation shall have a unique number that matches one of the buses contained in the substation
Sub Name	Substation Name	Up to 12 characters with a unique name (substation name from WSM is recommended)
Sub Latitude	Geographic Latitude in decimal degrees	
Sub Longitude	Geographic Longitude in decimal degrees	

V. Dynamic Data Requirements

The Dynamic data for the Western Interconnection is maintained in the Master Dynamic File (MDF). To provide consistency in data submittals and help avoid potential solution problems in the reliability analysis of the interconnected transmission system, Data Submitters shall submit dynamic data to WECC per the guidelines listed herein. However, WECC recognizes deviations from the guidelines may occasionally be needed. For these situations, submitters are requested to provide the SDWG and MVWG with the rationale for exceptions. In all cases, dynamic data must be consistent with steady-state data provided for each WECC Base Case. Data Submitters are responsible for providing data for facilities in the WECC approved format.

Dynamic data is submitted as soon as any new data becomes available. Dynamic data may become available outside the scheduled case building process as a result of individual entity equipment testing programs such as the generator testing program.

Dynamic data for new generators and updates for existing generators are submitted via the WECC Generating Unit Model Validation Policy. The WECC Generating Unit Model Validation Policy includes the roles and responsibilities of the Generator Owner, the Transmission Planner, and WECC.

Approved dynamic models conform to the WECC Dynamic Modeling Procedure. All dynamic models contained in the MDF shall be those approved by MVWG. If the model you want to use is not on the approved list, you must go through MVWG and follow the WECC Dynamic Modeling Procedure.

The following approach to dynamic data shall apply Interconnection-wide:

- Generators and other dynamic devices shall be represented with approved dynamic data as recommended by the MVWG to represent the designated dynamic equipment modeled in WECC Base Cases. The approved models can be found within the Approved Dynamic Model Library
- When new models have been added to or obsolete models have been removed from the Approved Dynamic Model Library, Data Subcommittee and SDWG will determine an appropriate implementation schedule and scope for submitting the necessary data required by the newly approved models.
- Estimated or typical manufacturer's dynamic data based on facilities of similar design and characteristics may be used to represent planned generators and other dynamic devices if specific design data cannot be obtained. MVWG maintains the Typical Machine Data document. Specific dynamic design data shall be submitted per the WECC Steady-State and Dynamic Data Criterion. See "[General Data Requirements and Reporting Procedures](#)"

- Where there is a difference between the requirements of this document and the WECC Generating Unit Model Validation Policy, the WECC Generating Unit Model Validation Policy shall preside.
- Typical dynamics studies are up to 60 seconds from the initiating event. All models, on the Approved
- Dynamic Model Library list that can respond within that time frame shall be submitted.

Generation Requirements

1. Dynamic data for generators, synchronous condensers, excitation systems, voltage regulators, turbine governor systems, power system stabilizers, and other associated generation equipment shall be derived from test results obtained by adhering to the WECC Generating Unit Model Validation Policy for each unit represented in WECC Base Cases according to thresholds as specified in Section IV. This includes, as appropriate to the model, items such as inertia constant, damping coefficient, saturation parameters, and direct and quadrature axis reactances and time constants.
2. Generator Owners shall submit power plant data in accordance to the voltage and MVA size thresholds for aggregating generator models described in the Section IV. (see [Section “Generation”](#))
3. Netting of planned generators represented in WECC Base Cases shall conform to the threshold requirements of the Section IV.
4. The MWCAP parameter in the dynamic turbine-governor model shall be greater than or equal to the Pmax parameter of the generator steady-state model to avoid governor initialization problems.
5. Power System Stabilizer (PSS) Dynamic data shall be submitted for all generators that have active PSS. See the WECC Policy Statement on Power System Stabilizers document.
6. Existing generators shall follow the WECC Generating Unit Model Validation Policy.
7. User defined models for collector based generator (Wind and Solar plants) representation shall be avoided.

Load Requirements

Model voltage and frequency characteristics explicitly for each individual load if possible. However, use Composite Load Model for loads for which frequency and voltage characteristics are not explicitly known. The goal of this section is to model effects of voltage and frequency on load as accurately as possible.

1. A composite load model shall exist for each load modeled in the steady-state data.
2. Keep dynamic load data characteristics consistent with reported steady-state data.

3. For loads less than 5 MW, Data Submitters will work with WECC staff to establish a default load representation record for each Area to represent loads not modeled with the Composite Load Model. This is to avoid the load representation defaulting to constant power (PSLF default). If actual dynamic load characteristics are not available, load should be modeled as constant current P, and constant impedance Q. Bus specific exceptions to the default load representation must be submitted to WECC staff for inclusion in the MDF.

Underfrequency Load Shedding (UFLS)

1. Include Underfrequency Load-Shedding records for all loads that have underfrequency relays on the interconnected system.
2. Ensure the pickup frequency of each stage is lower than that of the previous stage. UFLS must comply with WECC-coordinated off-nominal requirements as specified in the WECC Off-Nominal Frequency Load-Shedding Plan document.
3. Include pertinent load data in the MDF. All Underfrequency Load-Shedding data in the MDF must match bus, load, and/or branch identifiers in the cases.
4. Ensure UFLS models provided correspond to UFLS information provided to WECC Underfrequency Load-Shedding Review Group in accordance with WECC Underfrequency Load-Shedding Criterion.

Undervoltage Load Shedding (UVLS)

1. Include undervoltage load-shedding records for all loads that have undervoltage relays on the interconnected system.
2. Coordinate the pick-up and time-delay setting for each stage with the previous stage.
3. Include pertinent load data in the MDF. All undervoltage load-shedding data in the MDF must match bus, load, and/or branch identifiers in the cases.

Relays

Include relay models as approved for use by the SDWG per the time line and scope it establishes for primary relays. Data submitters are also strongly encouraged to submit all relevant backup relay modeling data.

Back-to-Back DC Ties

Netting is allowed for back-to-back DC ties. Represent back-to-back DC ties as generation in the power flow, but netted in dynamic data. The record should include an ID designation of 'DC' on the generator record.

DC Lines, SVC and D-VAR systems

1. Device-specific dynamic data for dynamic devices shall be modeled, including but not limited to static VAR compensators and controllers, high-voltage direct-current systems, flexible AC transmission systems, and automatically switched shunt and series capacitors or reactors.
2. Model, to the maximum extent possible, DC lines and SVC systems to accurately reflect actual system performance.
3. Coordinate DC bus numbering with WECC staff prior to model submission.

VI. Remedial Action Scheme and Associated Contingency Data

Remedial Action Scheme (RAS) and associated Contingency data shall be shared with WECC and WECC shall securely store the information separate from the interconnection-wide cases.

The following approach should be taken when providing contingency and RAS data:

- All models should be provided upon request by Data Submitters in their preferred format until the WECC common format is available in the providers preferred software.
- RAS models should be provided if the affected elements are modeled in the case.
- All models should identify the data owner by naming the models with the member system acronym and an underscore at the front. (i.e 'member system acronym' 'descriptive model name')
- RAS and associated contingency models shall be provided for all operations base cases. These are denoted by an "-OP" in the base case compilation schedule. New models shall be provided when the RAS are placed in use by the Operations department of each member, while existing models need only be updated when changes occur. Data Submitters shall notify WECC staff if any already provided models are no longer online and should be removed.
- RAS data will be made available on the WECC website. It will only be accessible to those users who are logged in and authorized to access it.

Disclaimer

WECC receives data used in its analyses from a wide variety of sources. WECC strives to source its data from reliable entities and undertakes reasonable efforts to validate the accuracy of the data used. WECC believes the data contained herein and used in its analyses is accurate and reliable. However, WECC disclaims any and all representations, guarantees, warranties, and liability for the information contained herein and any use thereof. Persons who use and rely on the information contained herein do so at their own risk.

Appendix 1 – Late Data Procedure

The objective of the Late Data Procedure is to preserve the original schedule for the development of base cases in accordance with each year's Data Bank Compilation Schedule, and the Case Description sheet in the data request letter for each case. The Late Data Procedure describes Data Submitter and staff data submittal responsibilities as well as actions to be taken for actual delays or anticipated delays in the submittal of data, or for the submittal of unusable data. This procedure does not take effect until one of the following occurs:

- A data submittal date has been missed; or
- There is sufficient reason to believe that a submittal date will be missed; or
- It is determined that the submitted data is not usable.

Success of the case development program depends on timely and accurate data submittal, review, and support of the development of each base case. A Data Submitter not meeting a scheduled response date listed in the Data Bank Compilation Schedule with a usable response could result in a delay in the case development schedule if left uncorrected.

Examples of unusable data:

- Data from two neighboring Data Submitters with inter-area schedules that do not match; and
- Data with such significant problems that it cannot be used for the comment phase of the development process which; therefore, delays the progress of the case development.

Any unusable data received by the WECC staff must be corrected by the Data Submitter so as to not further impair the schedule or it will be rectified in accordance with this Late Data Procedure, as will any late data or anticipated late data.

Data Submitter and Staff Responsibilities

It is the responsibility of Data Submitters to submit timely and accurate data in accordance with the Data Bank Compilation Schedule and the Case Description sheet in the data request letter. A schedule can be impaired either by data being submitted after the scheduled due date or by the submission of unusable data, even if it is submitted on time.

If, in the judgment of WECC staff, it appears that the schedule will be impaired due to lack of usable data response by the Data Submitters, it will be the responsibility of WECC staff to provide the data for the case in question.

Actions to Take

There are two actions specified by this procedure in the event the WECC staff has to exercise its late data responsibilities for a delinquent entity. The first is the action of assuming the responsibility for submitting the data and the second is the notification of such action. If the staff takes over the responsibility for the submittal of data for the delinquent entity, the data to be submitted should always be the best data available in the judgment of the person submitting the data. The data should be submitted in such a way that the original schedule is maintained or not further impaired.

At the time the WECC staff takes over data submittal responsibility for a Data Submitter:

1. The WECC staff will notify the Data Submitter and copy the notification of the action taken to:
 - a. RAC and Data Subcommittee representatives of the Data Submitter; and
 - b. SDWG.
2. When the case involved is an operating case for OTC studies, the staff will send a notification letter to:
 - a. The Operating Committee (OC) and the Operating Transfer Capability Policy Group Study Group (OTCPGSG).

The notification will consist of the nature and extent and reasons of the action taken. Those who consistently abuse the base-case development process by submitting late or unusable data may be significantly compromising the reliability of the Western Interconnection transmission system.

Backfitting of Late Data

The Late Data Procedure allows for the WECC staff to take over data submittal responsibilities for a Data Submitter in the event that entity is unable to submit usable data in accordance with the defined schedule. If the Data Submitter's data should subsequently become available, the data shall be submitted to the WECC staff to partially or fully replace that which was previously submitted. However, the staff may refuse to accept this backfit data if, in its judgment, the backfit data is no better than the data already in the case or if there would be unacceptable impairment of the schedule by accepting the backfit data.

Appendix 2 – Area, Zone and Bus Number Assignments

Southwest Region

Area Number Range 10 – 19
 Zone Number Range 100 – 199
 840 – 859
 1000 – 1999
 Bus Number Range 10,000 – 19,999
 84,000 – 85,999
 100,000 – 199,999

**Member System
 Bus Range**

Area No.	Zone Range	Area Name	Member System	Member System Bus Range
10	100 - 109	New Mexico	PNM	10,000 – 10,999
	1000 - 1099			100,000 – 109,999
	120 - 139	New Mexico	TSGT	12,000 – 12,999
1200 - 1399	120,000 – 129,999			
11	110 – 119	El Paso	EPE	11,000 – 11,999
	1100 - 1199			110,000 – 119,999
14	140 - 149	Arizona	APS	14,000 – 14,999
	840 - 859			84,000 – 85,999
	1400 - 1499			140,000 – 149,999
15	150-159	SRP	SRP, APA	15,000 – 15,999
	1500-1599			150,000 – 159,999
16	160-169	TEP	TEP, UES	16,000 – 16,999
	1600 - 1699			160,000 – 169,999
17	170-179	AEPCO	AEPC, Others	17,000 – 17,999
	1700 - 1799			170,000 – 179,999
18	180 – 188	Nevada	NEVP	18,000 – 18,899
	1800 - 1889			180,000 – 188,999
	189			18,900 – 18,999
19	1899		VEA	189,000 – 189,999
	190-199	WAPA-L.C.	WAPA-L.C.	19,000-19,999
1900-1999	190,000-199,999			

Southern California Region

Area Number Range 20 – 26
 Unused Areas 27 – 29
 Zone Number Range 200 – 299
 2000 – 2999
 Bus Number Range 20,000 – 29,999
 94,000 – 95,999
 200,000 – 299,999

**Member System
 Bus Range**

Area No.	Zone Range	Area Name	Member System	Member System Bus Range
20	200 – 209	Mexico – CFE	CFE	20,000 – 20,999
	2000 - 2099			200,000 – 209,999
21	210 – 219	Imperial, CA	IID	21,000 – 21,999
	2100 – 2199			210,000 – 219,999
22	220 – 239	San Diego	SDGE	22,000 – 22,999
	2200 – 2399			220,000 – 229,999
			Others	23,000 – 23,999 230,000 – 239,999
24	240 – 259	So Calif	SCE	24,000 – 24,999
	2400 – 2599			240,000 – 249,999
				94,000 – 95,999
				29,000 – 29,999
				290,000 – 299,999
			CDWR, MWD, Others	25,000 – 25,999 250,000 – 259,999
26	260 – 289	LADWP	LDWP	26,000 – 26,999
	2600 – 2899			260,000 – 269,999
			BURB, GLEN	27,000 – 27,999 270,000 – 279,999
			Others	28,000 – 28,999 280,000 – 289,999

Northern California Region

Area Number Range	30
Unused Areas	31 – 39
Zone Number Range	300 – 399 3000 – 3999
Bus Number Range	30,000 – 39,999 300,000 – 399,999

Area No.	Zone Range	Area Name	Member System	Member System Bus Range
30	300 – 399	PG and E	PG&E	30,000 – 36,999
	3000 – 3999			300,000 – 369,999
			SMUD	37,000 – 37,499 370,000 – 374,999
		WAPA	SNR	37,500 – 37,899 375,000 – 378,999
			REU	37,900 – 37,999 379,000 – 379,999
			NCPA	38,000 – 38,199 380,000 – 381,999
			MID	38,200 – 38,399 382,000 – 383,999
			TID	38,400 – 38,599 384,000 – 385,999
			CDWR	38,600 – 38,899 386,000 – 388,999
			Others	38,900 – 39,999 389,000 – 399,999

Northwest Region

Area Number Range	40
Unused Areas	41 – 49
Zone Number Range	400 – 499
	4000 – 4999
Bus Number Range	40,000 – 49,999
	90,000 – 90,999
	400,000 – 499,999

Member System
Bus Range

Area No.	Zone Range	Area Name	Member System	Member System Bus Range
40	400 – 499	Northwest	BPA, other Federal, WPPSS, Detailed Federal hydro	40,000 – 41,999
	4000 – 4999			44,000 – 44,499
				400,000 – 419,999
				440,000 – 444,999
			PSE	42,000 – 42,999
				420,000 – 429,999
			PGE	43,000 – 43,999
				430,000 – 439,999
			PACW	44,500 – 45,599
				445,000 – 455,999
			SNPD	45,600 – 45,999
				456,000 – 459,999
			GCPD	46,000 – 46,199
				460,000 – 461,999
			EWEB	46,200 – 46,399
				462,000 – 463,999
			SCL	46,400 – 46,599
				464,000 – 465,999
			TPWR	46,600 – 46,799
				46,900 – 46,999
				466,000 – 467,999
				469,000 – 469,999
			CHPD	46,800 – 46,899
				468,000 – 468,999
			Others – Public	47,000 – 47,499
				470,000 – 474,999
			Others – Private or IOU	47,500 – 47,999
				475,000 – 479,999
			AVA	48,000 – 49,999
				480,000 – 499,999
			All members	90,000 – 90,999

Canadian Region

Area Number Range	50, 52, 54
Unused Areas	51, 53, 55 – 59
Zone Number Range	500 – 599
	5000 – 5999
Bus Number Range	50,000 – 59,999
	80,000 – 81,999
	500,000 – 599,999

Area No.	Zone Range	Area Name	Member System	Member System Bus Range
50	500 – 519	BC Hydro	BCHA	50,000 – 51,999
	5000 – 5199			500,000 – 519,999
				80,000 – 81,999
52	520 – 539	Fortis BC	FBC	52,000 – 53,999
	5200 – 5399			520,000 – 539,999
54	540 – 599	Alberta	AESO	54,000 – 59,999
	5400 – 5999			540,000 – 599,999

Central Region

Area Number Range	60, 62 – 65
Unused Areas	61, 66 – 69
Zone Number Range	600 – 699
	6000 – 6999
Bus Number Range	60,000 – 69,999
	600,000 – 699,999

Area No.	Zone Range	Area Name	Member System	Member System Bus Range
60	600 – 619	Idaho	IPC	60,000 – 60,999
	6000 – 6199			600,000 – 609,999
			BPA, Others	61,000 – 61,999 610,000 – 619,999
62	620 – 629	Montana	NWMT	62,000 – 62,999
	6200 – 6299			620,000 – 629,999
63	630 – 639	WAPA UGP	WAUW	63,000 – 63,999
	6300 – 6399			630,000 – 639,999
64	640 – 649	Sierra	SPP	64,000 – 64,999
	6400 – 6499			640,000 – 649,999
65	650 – 699	Pace	PACE-UT, WY, ID	65,000 – 69,999
	6500 - 6999			650,000 – 699,999

Eastern Region

Area Number Range	70, 73
Unused Areas	71, 72, 74 – 79
Zone Number Range	700 – 799 7000 - 7999
Bus Number Range	70,000 – 79,999 700,000 – 799,999

Area No.	Zone Range	Area Name	Member System	Member System Bus Range
70	700 – 719	PSColorado	PSC, WPE, TSGT	70,000 – 70,999
	770 - 789			700,000 – 709,999
	7000 – 7199			71,000 – 71,999
	7700 – 7899			710,000 – 719,999
				77,000 – 78,999
73	720 – 769	WAPA R.M.	TSGT	720,000 – 729,999
	790 – 799			
	730 – 799			
	7300 – 7999			
			WALM	73,000 – 73,999
				730,000 – 739,999
			BHPL	74,000 – 74,999
				740,000 – 749,999
			PRPA	75,000 – 75,999
				750,000 – 759,999
			BEPC	76,000 – 76,999
				760,000 – 769,999
			WAUC	79,000 – 79,999
				790,000 – 799,999

Temporary Assignment

If requested, SRWG will assign and maintain the assignment of bus and zone numbers through coordination with the Data Submitter.

Area Number Range	Not Applicable
Zone Number Range	8000 - 8999
Bus Number Range	800,000 – 850,000

**Temporary
Assignment**

Miscellaneous Assignment

Area Number Range	Not Applicable	
Zone Number Range	Not Applicable	
Bus Number Range	97,000 – 99,999	Dummy Buses
	897,000 – 899,999	
	997,000 – 999,999	
Bus Number Range	1-9,999	Internal Use Buses

Revision History

Version	Version Date	Editor(s)	Revision Description
	June 26, 2012	Mark Mallard Gordon Comegys Doug Tucker	<ul style="list-style-type: none"> Added Turbine Type field for Generators Expanded bus number ranges for Areas Added dynamic data submittal requirement to include all devices that could respond within 60 seconds if an approved model exists
	October 12, 2012	Doug Tucker Gordon Comegys Don Streebel	<ul style="list-style-type: none"> Added language for sub-100-kV elements Fixed minor changes in text
	July 18, 2014	Jonathan Young Doug Tucker	<ul style="list-style-type: none"> Accommodate BES Definition Reword UVLS sections Added Short Circuit Data info Added Contingency and Remedial Action Scheme Data Bus number ranges slightly changed Few member Acronyms changed Fixed minor changes in text
BCCS	BCCS Version	Jonathan Young	<ul style="list-style-type: none"> Incorporated BCCS methodologies
BCCS-4	December 12, 2014 (SRWG Approval)	Jonathan Young J. Ramey	<ul style="list-style-type: none"> Added four digit zone number ranges WECC Technical Writer edits and formatting
BCCS-5	January 21, 2015	Jonathan Young John Gross	<ul style="list-style-type: none"> Incorporated MOD-032-1 implementation plan concepts
BCCS-5.1	April 24, 2015	John Gross	<ul style="list-style-type: none"> Incorporated PCC comments regarding MOD-032 implementation plan approach. PCC did not approve version BCCS-5.
6	August 12, 2015	Jonathan Young John Gross Andrew Christensen	<ul style="list-style-type: none"> Incorporated TSS comments to remove direct references to modeling standards. Removed references to BCCS and reinstated Master Tie-Line File language.
7	August 9, 2016	Jonathan Young	<ul style="list-style-type: none"> Substations Added language for BAs

7	August 10, 2016	Nicholas Hatton	<ul style="list-style-type: none">• Minor updates as directed by WECC technical writer
8	August, 2017	Sirisha Tanneeru	<ul style="list-style-type: none">• Added four DPM change requests – Change WAPA L.C. from Area 14 to Area 19, Turbine Type, Transformer Type, Swing Criteria and Branch Type• Changed existing WECC group names to the new RAC groups
9	November 11, 2017	Sirisha Tanneeru	<ul style="list-style-type: none">• Implemented RAS and APS Zones DPM change requests