



Jon Jensen

V2.1 vs. V2.2 Follow-Up

November 2, 2022

Jon Jensen

WECC Staff Engineer

Average Number of Starts Per Day

Unit	V2.1 Avg. Starts	V2.2 Avg. Starts
Apache GT4	1.02	0.6
CISC GT Agg Multi-Co 1	2.83	0.9
CT_88_IRP	1.29	0.3
Lange	1.01	0.9
LAX Airport Agg	2.16	0.9
Magnolia1	2.15	0.1
OLSchinoCC-Total	1.07	0.8
Pueblo Airport 1	1.26	0.7
Pueblo Airport 2	1.26	0.6
Scat CC1	1.74	0.5
Scattergood CC3	1.06	0.6

EPE TEPC Nomogram

Nomogram	Penalty price hit (\$1,000) V2.1	Penalty price hit (\$20) V2.2
TEP Local Gen	8	10
EPE Balance	2,623	497

Geothermal

- All Geothermal units were fixed
 - Now modeled not as Natural Gas
 - Updated heat rate
 - Modeled as Must Run
 - New Forced Outage rate



Contact:

Jon Jensen

WECC Staff Engineer

jjensen@wecc.org