

# NERC

NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION

# Assuring a Reliable BPS through the Expansion of Interregional Transfer Capability: NERC ITCS

Saad Malik

Manager, Transmission Assessments

**WECC Reliability Assessments Committee**


**October 16, 2024**

**RELIABILITY | RESILIENCE | SECURITY**




# Across an Interconnected System: Less Resources Means More Reliance on Neighbors


## 2012 and 2022 Peak Capacity Resource Mix NERC-Wide




## NERC-Wide Summer Peak Demand Changes 2012 and 2022



## 2024-2033 Risk Areas





## NERC-Wide Projected Summer Peak Demand Growth (2034)



# Recent Examples Highlight Need for Wide-Area Energy Assessments

**June 6, 2023: ERCOT, SPP, MISO: A “wind drought” caused 60 GW of installed wind capacity to generate 300 MW**



**December 24, 2022: PJM:**  
Transmission system during extreme cold weather limited the ability to export to support southern neighbors




## Fiscal Responsibility Act (FRA), Section 322

*In consultation with the Regional Entities and transmitting utilities, NERC shall conduct a study containing three elements:*

1. **Current total transfer capability**, between each pair of neighboring transmission planning regions.
2. A recommendation of **prudent additions to total transfer capability** between each pair of neighboring transmission planning regions that would demonstrably strengthen reliability within and among such neighboring transmission planning regions.
3. Recommendations on **how to meet and maintain the identified total transfer capability**, together with the prudent recommended additions in #2.

# ITCS Timeline Overview

The following is a timeline of upcoming key activities:



# ITCS Study Overview

## What the Study **is**:

- Assessed adequacy of North American interregional transmission system
- Foundational, Groundbreaking Work
- Identifies areas that may suffer energy deficiencies under extreme weather and will benefit from additional transfer capability
- Credible technical analysis, with consistent assumptions, and results that are coordinated with the industry
- Sets the stage for more in-depth studies in future

## What the Study **is NOT**:

- Does not match every planning region's modeling approaches
- Does not prescribe specific projects
- Does not prescribe the "how", but "what" may be needed
- Does not evaluate market-based dispatched, or operational mitigations
- Is not the final step in the process (FERC will request public comments)
- Does not evaluate economics or policy
- A complete planning study



# Transfer Capability Observations and Findings



## Varies Widely

- Current transfer capability changes (TTC) as percentage of peak load = 1% to 92% between regions, varying greatly depending on season and online generation dispatch



## Transmission May Not Always be a Solution

- New transmission will not always increase transfer capability
- Voltage and dynamic stability limitations will determine how much power can be transferred



## Resource Evaluation Cannot be Overlooked


- Many areas do not have sufficient committed generation to meet demand under extreme conditions (2034)
- Canadian system critical to this evaluation



## Higher TTCs Will Require Significant Planning and System-Wide Reinforcements


- TTC additions will require more granular stability studies once specific projects are evaluated
- Meaningful TTC additions will not be completed by 2034 without regulatory/legislative changes

<sup><Public></sup>  
**Part I Total Import Capabilities as  
Percentage of 2024 Peak Load (Summer)**






<sup><Public></sup>  
**Part I Total Import Capabilities as  
Percentage of 2024 Peak Load (Winter)**






<Public>  
**What is Technically Prudent Additions  
to Transfer Capability?**




FERC precedent provides that “prudence” means a determination of whether a reasonable entity would have made the same decision in good faith under the same circumstances, and at the relevant point in time.

# Pipe and Bubble Model






# Pipe and Bubble Model




# Part II: Prudent Additions Recommendations






# Energy Assessment: Cold Snap Example


Maximum Daily Load (% of Annual Peak)




Average Daily Wind & Solar Capacity Factor (%)



Daily Thermal Outage Rate (% of Total)




Minimum Daily Margin (% of Load)




Source: ESIG Transmission Resilience Task Force (Telos Energy)  
<https://www.esig.energy/transmission-resilience/>

<Public>  
**Energy Assessment to Identify  
Prudent Additions**




<Public>  
**Energy Assessment Maximum  
Deficiency Identified (Preliminary)**



- Capacity expansion determined by projections in Long-Term Reliability Assessment
- Tightening energy margins driven:
  - assumed extreme weather conditions
  - increased load growth
  - on-going retirement of conventional generation
  - shift toward a higher proportion of variable (wind and solar)
  - energy-limited resources (e.g., battery storage).
- Number of hours in these conditions range from 1-20

# Prudent Addition Recommendations (Preliminary)



# Recommended Prudent Additions (Preliminary)

## Recommended Prudent Additions

Transmission Planning Region	Events / Drivers	Event Seasons	Interface for Additions	Prudent Addition Recommendation (MW)
Northern California	2022 Heat Wave	Summer	Wasatch Front	1,100
ERCOT	Winter Storm Uri (2021) and four other events	Summer and Winter	Front Range, MISO-S, SPP-S	15,100
SPP-S	Winter Storm Uri (2021)	Winter	ERCOT, Front Range, MISO-W, SERC-C, SPP-N	3,700
MISO-E	2020 and two other events	Summer	MISO-W, PJM-W	3,000
MISO-S	2009 and 2011	Summer	ERCOT, SERC-SE	600
SERC-FL	Summer 2009 and Winter 2010	Summer and Winter	SERC-SE	1,200
SERC-E	Winter Storm Elliott (2022)	Winter	PJM-W, SERC-C, SERC-SE	4,100
PJM-S	Winter Storm Elliott (2022)	Winter	PJM-E	2,800
NYISO	2023 Heat Wave and five other summer events	Summer	PJM-E, Québec	3,700
ISONE	2012 and two other summer events	Summer	Québec, Maritimes	700
Total Prudent Additions Recommendations				36,000

# ITCS Insights On Prudent Additions

- 10 regions show energy deficiencies under extreme weather
- Transmission capacity can amplify benefits of demand response and storage (e.g., X MW of incremental transmission capacity can relieve 1.5-2x MW of energy deficit under certain conditions)
- Initial results show that transfer capability alone cannot resolve many deficiencies, without including Tier 2 additions (which are much less certain)
  - Western interconnection and ERCOT are short under planned additions and with expanded transfer capacity
  - Balance of US can meet demand with planned additions, confirmed retirements, and identified “prudent” transmission expansion
  - Duration of deficit conditions range from 1-20 hours (2033)




- Potential for energy inadequacy identified in all 12 studied weather years
- 36 GW of additional transfer capability is recommended across United States
- Import capability required during extreme weather varied significantly, so a one-size-fit-all minimum requirement may be inefficient and may be ineffective
- Enhancing some of the interregional ties between interconnections (Eastern, Western, ERCOT and Quebec) provides considerable benefits under extreme weather conditions
- Total simultaneous import capability is also critical


# Plans for Canadian Analysis

Calculate	Calculate US to Canada transfer capability
Calculate	Calculate inter-provincial transfer capability
Calculate	Simultaneous import capability into each region
Perform	Perform energy margin analysis
Recommend	Recommend prudent additions


# Example of Prudent Addition Analysis: SERC-E (2033)



**First Iteration:** Utilize Existing Import Capability and Excess Available Generation from Neighbors



**Third Iteration:** Maximum Support from Neighbors, Prioritized by Excess Available Generation



5,463 MW of Existing Import Capability + 4,100 MW of Prudent Additions =  
**9,563 MW of Needed Import Capability**



# Questions and Answers