



# PNNL Methodology and Results Evaluating Balancing Reserve Requirements for WECC 2034 ADS Case

**Nader Samaan & Allison Campbell**

**PNNL Team:** Tony Nguyen, Quan Nguyen,  
Tao Fu, Lauren Henderson

**WECC Production Cost Data Subcommittee Meeting**

October 29<sup>th</sup>, 2025



**BATTELLE**


PNNL is operated by Battelle for the U.S. Department of Energy






# Agenda


- Main Take-Aways from 2034 Balancing Reserve Calculations
- PNNL Balancing Reserve Calculation Approach
- Data Collection and Processing for WECC ADS PCM 2034 Reserve Calculations
- Sample of Reserve Calculations Results for Selected BA
- Conclusions for 2034 Balancing Reserves
- Appendix
  - Data processing
  - Modeling of Load Following and Regulation Constraints in GridView




Load (red)



Wind



Solar



Reserve  
deployment

# Main Take-Aways from 2034 Balancing Reserve Calculations


# 2034 Balancing Reserve Results

- High increase of solar (utility and BTM) and wind installed capacity in the the WECC 2034 ADS case compared to the WECC 2032 ADS case
- New hourly utility scale solar and wind profiles are created based on 2018 weather models for new plants that did not exist in the 2032 case
- High-resolution time series (at least 5-min) is key for estimating flexibility requirements
- PNNL calculated Load Following (LF) and Regulation (Reg) up and down capacity requirements
  - Results to be incorporated in WECC ADS 2034 case at the BA level in Hitachi GridView
- As an example, in CAISO,
  - LF requirements increased by ~1000 MW up/down (January).
  - Reg requirements shifted towards off-peak and mid-day time periods, that would require further investigation and may suggests the need for improvement in the methodology used to create 1-min data.

# PNNL Balancing Reserve Calculation Approach

# Generation Flexibility Assessment as Input to Production Cost Model

## PNNL's Grid Reserve and Flexibility Planning Tool (GRAF-Plan)





# Summary of PNNL's Reserve Calculation Methodology


- Mimics real balancing process, including scheduling and real-time dispatch
- Incorporates both variability and uncertainty factors
- Includes all sources of uncertainty (native load, wind, solar, behind-the-meter solar)
  - Reflects forecast errors and their impact on balancing requirements
- Evaluates both capacity requirements and ramping requirements
- Flexible to reflect differences between balancing processes in different systems
- Has been benchmarked against actually observed balancing requirements
- Has been used in multiple studies

# Net Load and Generation Requirement


- BA Hourly Net Load = Load – Wind – Solar + Interchange
- Net Load = Generation Requirement
- Scheduled Generation Requirement = Forecasted Net Load
- Actual Generation → Actual Net Load  $\pm \Delta$
- Generation Requirement:
  - Energy schedules
  - Real time dispatch (load following)
  - Regulation




# Modeling Variability and Uncertainty (Hour-Ahead Forecast)




# Block Hour-Ahead Net Load Schedules



# Real-Time Scheduling




# Balancing Reserves Components






# Load Following and Regulation

- **Load Following:** difference between hourly energy schedule including 20-min ramps (red line) and short-term 5-min forecast/schedule and applied “limited ramping capability” function (blue line)
- **Regulation:** difference between actual generation requirement and short-term 5-minute dispatch (red area between blue and green lines)




# Example of Load Following and Regulation Requirements

- Generate hour-ahead and 5-min ahead forecast errors for load, wind and solar.
- Use actual and forecast data to derive minute-by-minute load following and regulation requirements for each BA.



Load following requirements



Regulation requirements

# Data Collection and Processing for WECC ADS PCM 2034 Reserve Calculations

## WECC 2034 ADS PCM Planning

- WECC develops Anchor Data Set for 2034 model, including Production Cost Model case in Hitachi GridView software tool
- PNNL supports this planning activity by:
  - Providing utility scale wind and solar hourly profiles based on 2018 weather models for new plants that were not in the 2032 case
  - Applying PNNL-developed methodology to calculate flexibility reserves for the year of 2034
- Variability from wind and solar generators creates the need for operating reserves. This operating reserve calculation work is necessary to mitigate impacts of variability from these resources.



# Wind and Solar Summary in WECC 2034


Data Resource	Wind Capacity (MW)	Solar Capacity (MW)
2022 capacity (WECC 2022 State of Interconnection Report)	29,000	30,000
GridView database for WECC 2030 (v. 2.3)	35,723	39,908
GridView database for WECC 2032 (v. 2.1)	45,092	62,403
GridView database for WECC 2034 (v. 3.1)	53,301	86,677

## Summary at the BA level:


Types of installed capacity	AESO	AVA	AZPS	BANC	BCHA	BPAT	CAISO	CFE	CHPD	DOPD	EPE	GCPD	IID	IPCO	LDWP	NEVP	NWMT
Onshore Wind (MW)	5893	249	1635	0	1455	5200	15083	40	0	0	300	0	0	692	435	0	2072
Offshore Wind (MW)	0	0	0	0	0	0	3855	0	0	0	0	0	0	0	0	0	0
PV (MW)	0	0	2068	0	0	201	17109	900	0	0	0	0	0	40	2	2	0
SolarPV-Tracking (MW)	965	0	687	385	17	819	4469	0	0	0	840	0	237	745	800	4233	0
SolarPV-NonTracking (MW)	2544	19	1019	0	15	131	17116	50	0	0	3	0	546	116	1072	6296	177
Solar CSP (MW)	0	0	250	0	0	0	917	0	0	0	0	0	0	0	0	0	0
BTM (MW)	583	56	3764	1360	0	128	37740	0	0	1	159	1	109	106	850	1817	173
Peak Load (MW)	13076	2466	10947	5417	12995	13435	57945	5391	777	805	2587	1438	1206	5543	8251	10767	2247
Net Peak Load (Peak Load - BTM) (MW)	13076	2447	10410	5000	12995	13434	53536	5391	777	805	2501	1438	1170	5516	8033	10566	2230

Types of installed capacity	PACE	PACW	PGE	PNM	PSCO	PSEI	SCL	SRP	TEPC	TH_M	TH_P	TIDC	TPWR	WACM	WALC	WAUW
Onshore Wind (MW)	4973	836	717	2861	3729	565	0	356	554	0	0	0	0	1315	485	0
Offshore Wind (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PV (MW)	6	284	48	470	292	0	0	1525	100	0	0	0	0	273	0	0
SolarPV-Tracking (MW)	2984	299	0	1741	1842	200	0	1800	508	0	0	0	0	674	6867	0
SolarPV-NonTracking (MW)	491	267	128	110	297	0	0	353	55	0	0	0	0	274	0	0
Solar CSP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BTM (MW)	2080	945	145	527	2768	498	43	426	479	0	0	113	13	164	78	3
Peak Load (MW)	11445	4943	5201	3192	9950	5474	1712	11576	4318	0	0	785	795	6803	1600	167
Net Peak Load (Peak Load - BTM) (MW)	10658	4839	5150	3026	9227	5474	1712	11421	4163	0	0	753	795	6729	1554	166


# Wind Capacity Comparison between 2030, 2032, and 2034 Cases



# Utility Scale Solar Capacity Comparison between 2030, 2032, and 2034 Cases




# BTM Solar Capacity Comparison between 2030, 2032, and 2034 Cases






# Peak Native Load Comparison Between 2030, 2032, and 2034 Cases



# Net Peak Load (Native Load – BTM) Comparison Between 2030, 2032, and 2034 Cases



## Data Needs for PNNL Flex Reserve Calculation Tool (GRAF-Plan)


- 1-min net load (native load – BTM solar), wind and utility scale solar
- PNNL converted WECC ADS 2034 hourly native load data into 1-min resolution
- PNNL converted WECC ADS 2034 hourly BTM solar data into 1-min resolution
- NREL team developed 1-hour and 5-min solar data from separate models
- NREL team developed 1-hour wind data, 5-min wind data
- PNNL developed 1-hour and 1-min solar and wind data for new projects that did not exist in the 2032 case

# Data Processing Methodology

- Full discussion of data processing methodology, which takes the 5-min wind, load, and solar data, and converts them into 1-min, can be found in the appendix.

# CAISO Net load (Native Load — BTM\_Solar — Utility Scale Solar — Wind) (Jan 2034 days)

The resulting time series, which are fed into GRAF-Plan for processing, look similar to this; 1 minute resolution, with a clear diurnal shape due to BTM Solar and Utility Solar.





## Forecast Error Statistics Collection

- Analyze data from EIA (load and day-ahead load forecast)
- Analyze data from CAISO OASIS for:
  - Hour-ahead, real-time, and actual load
  - Hour-ahead and actual utility scale solar
  - Hour-ahead and actual wind data
- Analyze data from BPA for:
  - Hour-ahead and actual wind data

# Forecast Error Statistics and Other Assumptions


Parameter		Value								
L10 (used for each BA)		Example <b>CAISO 97.4 (2020)</b>								
		<a href="https://www.nerc.com/comm/OC/Documents/BAL-003_Frequency_Bias_Settings_02Jun2020.pdf">https://www.nerc.com/comm/OC/Documents/BAL-003_Frequency_Bias_Settings_02Jun2020.pdf</a>								
Swing Door Tolerance (regulation)		0.3 L10								
Swing Door Tolerance (load following)		0.6 L10								
		PV			CSP0			CSP6		
Solar - HA		Mean	StdDev	autocorr	Mean	StdDev	autocorr	Mean	StdDev	autocorr
	0<CI<=0.2	0	2.5%	0.8	0	2.5%	0.8	0	2.5%	0.8
	0.2<CI<=0.5	0	10%	0.8	0	10%	0.8	0	10%	0.8
	0.5<CI<=0.8	0	7.5%	0.8	0	7.5%	0.8	0	7.5%	0.8
	0.8<CI<=1.0	0	2.5%	0.8	0	2.5%	0.8	0	2.5%	0.8
Wind - HA		0	8%	0.9						
Net Load - HA		0	2%	0.9						
Wind and Solar - RT		Persistence model Forecast at time T = actual value at T-7.5 min, or average from -12.5 to -7.5								
Load - RT		0	0.15%	0.6						
Confidence Level		BA will Hold Capacity to Balance 95% of load following and regulation needs								

# Forecast Error Statistics and Other Assumptions

Parameter		Value
Truncation of Normal Distribution	Load Truncation	+/- 3 std aggregated at BA level
	Wind Truncation	+/- 4.5 std std aggregated at BA level
	Solar	0 and max value from clear sky curve at this hour for the plant
Load Following Occurrence	Every 5-min	
Number of Monte Carlo runs	30	
Monte Carlo random seed value, $s$ , for current run, $n$ , out of total runs, $N$	<ul style="list-style-type: none"> <li>• <math>s = (m - 1) \times 2 \times N + 2 \times (n - 1) + 101</math></li> <li>• <math>s</math> = seed value for this Monte Carlo iteration</li> <li>• <math>m</math> = month number (1 to 12)</li> <li>• <math>N</math> = total number of Monte Carlo runs (30)</li> <li>• <math>n</math> = current Monte Carlo run (1 to 30)</li> </ul>	


# Sample of Reserve Calculations Results for Selected BA

# CAISO 2032 vs. 2034 Load Following Requirements (January)






# CAISO 2032 vs. 2034 Regulation Requirements (January)



# CAISO 2034 Reserve Results by Source


- January Load Following
- July Load Following
- January Regulation
- July Regulation

# CAISO January 2034 Load Following decomposed (LF capacity needs by each individual resource)



Note: the total requirement (dark blue in the graph) is not a simple linear addition of individual components


# CAISO July 2034 Load Following decomposed (LF capacity needs by each individual resource)



Note: the total requirement (dark blue in the graph) is not a simple linear addition of individual components


# CAISO July 2034 Load Following decomposed

(Percent of each resource of total LF capacity)






# CAISO January 2034 Regulation decomposed (REG capacity needs by each individual resource)



Note: the total requirement (dark blue in the graph) is not a simple linear addition of individual components


# CAISO July 2034 Regulation decomposed (REG capacity needs by each individual resource)



Note: the total requirement (dark blue in the graph) is not a simple linear addition of individual components

# CAISO July 2034 Regulation decomposed

(Percent of each resource of total Reg capacity)



# Conclusions for 2034 Balancing Reserves

# Summary and Conclusions

- High increase of solar (utility and BTM) and wind generation expected in WECC by 2034
- WECC prepares datasets for Production Cost Model in GridView software, ADS 2034 case to support generation, transmission planning
- PNNL supports WECC by calculating generation flexibility requirements used as input in GridView
- High-resolution time series is key for estimating flexibility requirements
  - Native load, BTM, wind and utility scale solar must be all time synchronized - 2009 data adapted to 2034 scenario
  - 1-minute data generated for load, solar (BTM and plants), and wind, based on available profiles – interpolation and noise added to create realistic 1-min data
  - Forecast errors assumed based on EIA data and operational data from California ISO and BPA
- Load following and regulation results incorporated in WECC ADS 2034 case at the BA level in Hitachi GridView



# Thank you

**Nader Samaan, Ph.D., P.E.**

Team Lead (Bulk Energy Systems 1)  
Power Systems Modeling Group  
Pacific Northwest National Laboratory

Phone: (509) 375-2954 (W)

Email: [nader.samaan@pnnl.gov](mailto:nader.samaan@pnnl.gov)



# **GRAF-Plan Client Projects: Successful Implementation of the Tool in Operational Planning**

## Projects (1)

Load following and regulation requirements calculated by this methodology were benchmarked against actual load following and regulation applied in CAISO, BPA, PSE, NV Energy and Duke Energy

No.	Project Titles	Funding Sources	Project Duration
1	Integration of Wind Plant Output Forecasting into Utility Energy Management Systems (EMS)	DOE's Office of EERE	2008-2009
2	Developing Tools for Online Analysis and Visualization of Operational Impacts of Wind and Solar Generation	CEC	2009-2011
3	Predict Day-ahead Regulation Requirements for CAISO	CEC	2010-2011
4	Assessing the Value of Regulation Resources Based on Their Time Response Characteristics	CEC	2007-2008
5	Operational Impacts of Wind Energy Resources in the Bonneville Power Administration (BPA) Control Area	BPA	2008
6	CAISO 20% and 33% Renewables Penetration Study	CAISO	2007, 2009
7	Large-Scale PV Integration Study for NV Energy	NV Energy and DOE	2010-2012
8	WECC BA Consolidation Study	DOE	2009-2012
9	Energy Storage for Power Systems Applications: A Regional Assessment for the Northwest Power Pool (NWPP)	DOE	2009-2010



## Projects (2)

Load following and regulation requirements calculated by this methodology were benchmarked against actual load following and regulation applied in CAISO, BPA, PSE, NV Energy and Duke Energy

No.	Project Titles	Funding Sources	Project Duration
10	NWPP EIM Study	NWPP	2012-2013
11	Duke Energy PV Integration Study	Duke Energy	2013-2014
12	Honduras PV integration Study	DOS	2015-2016
13	Reserve Calculation Study: Guatemala, Nicaragua, Costa Rica, Panama, El Salvador, Honduras	DOS	2015-2019
14	WECC 2030 ADS Reserves	DOE	2020
15	Integrate GRAF-Plan into ABB GridView PCM	DOE	2020-2021
16	WECC 2032 ADS Reserves	DOE	2022
17	Reserve Calculation Study: Vietnam	DOS	2021-2023

## Projects (2)

GRAF-Plan is used by the U.S. Western Interconnection to calculate operational planning reserves, and has been integrated into ABB/Hitachi Gridview Production Cost Model

No.	Project Titles	Funding Sources	Project Duration
10	NWPP EIM Study	NWPP	2012-2013
11	Duke Energy PV Integration Study	Duke Energy	2013-2014
12	Honduras PV integration Study	DOS	2015-2016
13	Reserve Calculation Study: Guatemala, Nicaragua, Costa Rica, Panama, El Salvador, Honduras	DOS	2015-2019
14	WECC 2030 ADS Reserves	DOE	2020
15	Integrate GRAF-Plan into ABB GridView PCM	DOE	2020-2021
16	WECC 2032 ADS Reserves	DOE	2022
17	Reserve Calculation Study: Vietnam	DOS	2021-2023

# PNNL-ABB/Hitachi Technology Commercialization Project (TCF)

- Title: Deploying Intra-hour Uncertainty Analysis Tools to ABB/Hitachi's GridView,
- Duration: Two years from 1/2020 to 12/2021
- Tasks: This project will incorporate the following incremental capabilities to GridView,
  - PNNL forecast error generator functionality to model uncertainty associated with day-ahead, hour-ahead and real-time forecasts of solar, wind and load at the balancing authority level (BA)
  - Balancing reserve requirement calculation using PNNL “Swing Door” algorithm to add load following and regulation constraints at the BA level
  - Sub-hourly database and optimization capability using selected functions from PNNL System Intra-hour Operation Simulator (ESIOCS) to model 5-min market operations
- <https://www.energy.gov/articles/departments-energy-announces-2019-technology-commercialization-fund-projects>




## Projects (2)

GRAF-Plan has been applied in networked countries (Central America) and islanded countries (Vietnam)

No.	Project Titles	Funding Sources	Project Duration
10	NWPP EIM Study	NWPP	2012-2013
11	Duke Energy PV Integration Study	Duke Energy	2013-2014
12	Honduras PV integration Study	DOS	2015-2016
13	Reserve Calculation Study: Guatemala, Nicaragua, Costa Rica, Panama, El Salvador, Honduras	DOS	2015-2019
14	WECC 2030 ADS Reserves	DOE	2020
15	Integrate GRAF-Plan into ABB GridView PCM	DOE	2020-2021
16	WECC 2032 ADS Reserves	DOE	2022
17	Reserve Calculation Study: Vietnam	DOS	2021-2023



# Models for Balancing Requirements Uncertainty: Multidimensional Uncertainty Analysis

- In existing approaches, analysis is frequently limited to just one dimension of the uncertainty problem—capacity
- But capacity is not a single sufficient descriptor of the problem
- Demonstrate operational performance of power system through four basic metrics, forming “performance envelope”
  - *Capacity* ( $\pi$ ): required minute-to-minute amount of generation or change in generation output to meet variations in balancing requirements
  - *Ramp rate* ( $\rho$ ): slope of the ramp
  - *Ramp duration* ( $\delta$ ): duration of a curve’s ramp along the time axis
  - *Energy* ( $\epsilon$ ): integration of capacity over time; calculate as area between analyzed curve and time axis




# Assessment of Ramping Requirements

- Use swinging door algorithm to derive required capability ( $\pi$ ), ramp rate ( $\rho$ ), and ramp duration ( $\delta$ ).
- Populate triads ( $\pi_i, \rho_i, \delta_i$ ) into three-dimensional space.
- Determine boundary values for ( $\pi, \rho, \delta$ ) that specify the probability of being outside the box:



# Simulate Hour Ahead (HA) Forecast Errors – Load and Wind

- Simulate using a random number generator based on statistical characteristics of actual forecast errors
- Distribution of forecast errors is an unbiased Truncated Normal Distribution (TND)
- Calculate wind HA forecast errors at BA level (not wind plant level)




# Simulated Solar Forecast Errors

- Behavior of solar is different than wind:
  - In absence of clouds and fog, solar output is very predictable.
  - Cloud and fog impacts are less predictable and act quickly.
  - Many days have little appreciable variation caused by cloud cover.
  - For days with cloud cover, some hours are cloudless.




- Obtain clearness index ( $C_I$ ) by dividing observed horizontal global solar radiation  $R_g$  by horizontal extraterrestrial solar radiation  $R$ :

$$k = R_g/R$$

- Solar forecast errors vs. clearness index



Daily pattern of the solar radiation of clearness index.



Solar forecast errors vs. clearness index.




# Simulated Solar Forecast Errors (cont.)

- Time and weather conditions during a day can result in different solar forecast errors patterns:
  - Night Time — forecast error is zero,  $\varepsilon = 0$
  - Sunny Day — forecast error is small or close to 0,  $\varepsilon \rightarrow 0$ , when  $CI \rightarrow 1$
  - Very Cloudy Day — forecast error is limited or close to 0,  $\varepsilon \rightarrow 0$ , when  $CI \rightarrow 0$
  - Partly Cloudy Day — forecast error varies in wide range for intermediate values of  $CI$
- Standard distribution of solar forecast errors can be described as a function of  $CI$ .
- Use solar generation profiles, including actual solar generation and ideal solar generation, to calculate  $CI$ :

$$CI(t) = \frac{G_a^s(t)}{G_{max}^s(t)}, (t = 1, 2, \dots, n)$$

- Calculate solar HA forecast errors at solar plant level (not BA level)



Hypothetical distribution of the standard deviation of solar forecast errors depending on the clearness index.

CI	$\sigma_{HA}$
$0 < CI \leq 0.2$	5%
$0.2 < CI \leq 0.5$	10%
$0.5 < CI \leq 0.8$	7.5%
$0.8 < CI \leq 1.0$	5%

**Table 1.** Standard Deviation of HA Solar Forecast Errors Based on Clearness Index Level.



## Methodology

### *Create 1-min load data series for future year from estimated hourly load for that year and historical actual 5-min load series*

- WECC ADS 2034 has hourly native load for 39 load areas, how to calculate 1-min native load?
  - 1-min net load (1-min native load – 1-min BTM solar)
- Ideally, would like to have 2024 5-min load data for each WECC BA and impose this data variability on WECC 2034 hourly data
- Only BPA and CAISO post 5-min load data publicly
  - Superimposed this 5-min variability on other WECC BAs
    - ✓ Impose CAISO load variability on BAs with high BTM solar
      - All load areas in CA, NVE, AZPS
    - ✓ Impose BPA load variability on the remaining load areas with limited BTM solar


## Methodology – Load Data Preparation

### *PNNL approach to calculate 1-min load from estimated future hourly load and historical actual 5-min load*

- Calculate area 1-min normalized variability from historical 5-min area load
- Calculate area final 1-min ADS load
- Repeat process for load areas where 5-min historical load is available.
  - Currently, there are only two BAs (CAISO and BPA) with 5-min historical data available publicly.
- To calculate 1-min actual load for the future year of interest, consider using CAISO normalized error for load areas within CAISO footprint and BPA normalized error for remaining load areas in WECC system


# Methodology

Calculate the area 1-min normalized variability from historical 5-min area load




# Methodology

## Calculate the area final 1-min ADS load



## Wind Data Hourly vs. 1-min


- NREL provided 5-min and 1-hour wind power data for each wind project.
- For most of the projects, there is a good match between the two data sets.



# Methodology

## *Calculate 1-min wind data from 5-min simulated actual*



- NREL 5 min wind data (WTK-LED CONUS)
  - <https://developer.nrel.gov/docs/wind/wind-toolkit/wtk-conus-5min-v2-0-0-download/>
- 3Tier code to convert from 5-min to 1-min, modified from 5-min to 1-min
  - 3TIER. 2010. Development of Regional Wind Resource and Wind Plant Output Datasets. NREL/SR-550-47676. Work performed by 3TIER for the National Renewable Energy Laboratory, Golden, Colorado. Accessed September 15, 2014, at <http://www.nrel.gov/docs/fy10osti/47676.pdf>





# PNNL's Utility Scale 30-min Solar for New Projects

- Started with 2018 weather dataset from NSRDB (<https://nsrdb.nrel.gov/data-viewer>)
  - Downloaded the USA & Americas 4km dataset
  - Used the 30-minute resolution to generate solar profiles for new projects
  - Converted to power using several assumptions for each project (see table at right)
- Interpolated 30-min data to 1-min for reserve calculations (cubic spline)
- Compare to hourly average of 30-min data and hourly average of 1-min data
- For most projects, there is a good match between 1-min and averaged hourly data



## Assumptions

DC/AC ratio = 1.3

Azimuth = 180°

\*Tilt = 0°

Inverter efficiency = 96%

System losses = 11%

Ground coverage ratio = 0.1

Constant loss adjustment = 0

\*In SAM, 1-axis PV systems are modeled with tilt = 0°, where the "tilt" parameter refers to the horizontal rotation axis.


## Methodology

### ***Calculate 1-min utility scale and BTM solar from 5-min synthetic generation and 1-min historical actual generation***


- Start with historical actual 2012 data:
  - Based on 1-min actual generation, create a look-up table for the standard deviation of noise as a function of clearness index
- Apply to synthetic 2034 data:
  - Based on synthetic 5-min generation data, linearly interpolate to 1-min and calculate the clearness index at plant level
  - Based on the calculated clearness, determine the standard deviation of noise for 2034 using look-up table from 2012
  - Calculate the autocorrelation and normalized noise, which is combined with the standard deviation to produce actual noise
  - Use the interpolated 1-min generation and actual noise to get the actual 1-min generation

# Methodology

**Calculate 1-min utility scale and BTM solar from 5-min synthetic generation and 1-min historical actual generation**



# CAISO Net load (Native Load — BTM\_Solar — Utility Scale Solar — Wind) (July 2034 days)



# Modeling of Load Following and Regulation Constraints in GridView

- Hourly load following (up/down) and regulation requirements (up/down) at BA level
- Which gen units can provide load following and/or regulation, it can be set at the following levels:
  - Global level: Unit sub-type at system level or units sub-type at BA level
  - Local level: Individual units (will overwrite global level if provided unless global level is smaller)
- Units excluded in ADS 2032 model from providing flex reserve:
  - Wind and Utility Scale Solar
    - ✓ Could provide 100% of their current simulation hour  $P_{gn}$  as load following down
    - ✓ Could provide load following up and spinning reserve if curtailed
    - ✓ Not currently used in the model
  - Nuclear (needs to be set at unit level)
  - Run of the river hydro (reserve contribution factor in GridView is set to zero)
  - Most coal units (exceptions for few BAs like PACE and PACW)



# How to Set Limits of How Much Reserve can be Provided by Hydro Gen Units in GridView

## GridView enforces 3 constraints for each unit to provide reserve:

1. Reserve Contribution Factor (for Hydro units only)
  - How much reserve the unit can provide Up and Down as percentage of the unit Pmax, in the WECC ADS 2030 case
  - 0 for run of river hydro units
  - 0.1 for small hydro units
  - $\text{Min}(0.5, 1/\# \text{ of units})$  for dispatchable large hydro units
  - As an example 0.25 Reserve Contribution Factor for a 100 MW unit means this unit can provide:
    - ✓ 25 MW up (LF\_up + reg\_up + Spinning)
    - ✓ 25 MW down (LF\_down + reg\_down)
2. Unit Pmax
  - If this 100 MW unit is operating at 90 MW, it can only provide 10 MW up and 25 MW down



# How to Set Limits of How Much Reserve can be Provided by Hydro Gen Units in GridView

## 3. Limits set by unit ramp rate

- LF\_up and LF\_down is bounded by ramp rate per min \* 20min
- Reg\_up and Reg\_down is bounded by ramp rate per min \* 10min
- If this same 100 MW unit can only ramp 60 MW per hour, it can only provide:
  - ✓ 1MW/min \* 20min = up to 20 MW LF up or down and
  - ✓ 1MW/min \* 10min = up to 10 MW Reg up or down or spinning
  - ✓ If it provides 10 MW for Reg up reserve, it cannot provide spinning but can provide up to 10 MW for LF up

# How Much Reserve can be Provided by Thermal Gen Units in GridView

- Thermal units can provide reserve based on minimum of:
  - Bid Amount (MW)
  - Ramping Up/Down Rate \* Min(AS)
  - Upward: Cap – Dispatch
  - Downward: Dispatch – Pmin
- WECC 2034 ADS can provide up to 100% capacity for reserves
  - Bid amount is not defined in the database (e.g., Nuclear or some coal units can be adjusted by unit bids if don't want to provide reserves)
  - Ramping rate and ramping minutes are defined in the database

# How Much Reserve can be Provided by Wind and Solar Gen Units in GridView

- BTM Solar cannot provide reserve in WECC 2034 ADS
- Wind and Utility Solar can provide downward reserve based on
  - Hourly generation Amount (MW)
- Wind and Utility Solar can provide upward reserve based on
  - Hourly curtailment Amount (MW)
- Wind and Utility Solar can provide up to 100% of hourly generation for downward reserves
- Wind and Utility Solar cannot provide upward reserves

# Backup Slides on 2030 and 2032 ADS case efforts

# Wind and Solar Summary in WECC 2030

Data Resource	Wind Capacity (MW)	Solar Capacity (MW)
2022 capacity (WECC 2022 State of Interconnection Report)	29,000	30,000
GridView database for WECC 2030 (v. 2.3)	35,723	39,908
GridView database for WECC 2032 (v. 2.1)	45,092	62,403

## Summary at the BA level:

Types of installed capacity	AESO	AVA	AZPS	BANC	BCHA	BPAT	CAISO	CFE	CHPD	DOPD	EPE	GCPD	IID	IPCO	LDWP	NEVP
Wind (MW)	3,870	105	227	0	779	4,970	7,188	130	0	0	247	0	0	601	424	0
Solar (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	18	0	0
SolarPV-Fixed (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	20	0	0
SolarPV-Tracking (MW)	247	0	310	186	2	0	10,626	0	0	0	504	0	122	180	855	2,662
SolarPV-NonTracking (MW)	0	0	343	20	93	5	5,626	401	0	0	5	0	442	110	1,270	457
SolarCSP0 (MW)	0	0	0	0	0	0	481	0	0	0	0	0	0	0	0	0
SolarCSP6 (MW)	0	0	250	0	0	0	641	0	0	0	0	0	0	0	0	64
BTM (MW)	0	12	2,815	716	0	44	18,771	0	0	2	316	4	199	39	745	599
Peak Load (MW)	13,291	2,376	9,687	4,844	12,234	12,958	52,320	4,361	501	464	2,336	1,501	1,266	4,536	7,830	7,045
Net Peak Load (Peak Load - BTM) (MW)	13,291	2,375	8,866	4,678	12,234	12,956	48,037	4,361	501	464	2,188	1,500	1,172	4,510	7,409	6,825

Types of installed capacity	NWMT	PACE	PACW	PGE	PNM	PSCO	PSEI	SCL	SPPC	SRP	TEPC	TIDC	TPWR	WACM	WALC	WAUW
Wind (MW)	760	6,525	822	717	1,860	4,752	664	0	150	0	190	0	0	566	425	0
Solar (MW)	0	0	145	0	0	0	0	0	0	0	0	0	0	0	0	0
SolarPV-Fixed (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SolarPV-Tracking (MW)	0	2,265	505	0	695	988	6	0	1,158	2,331	335	0	0	547	1,213	0
SolarPV-NonTracking (MW)	17	1,830	728	0	154	648	0	0	153	91	177	0	0	20	0	0
SolarCSP0 (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SolarCSP6 (MW)	0	0	0	0	0	0	0	0	111	0	0	0	0	0	0	0
BTM (MW)	29	188	73	79	132	1,513	24	6	83	438	433	192	1	60	324	2
Peak Load (MW)	2,090	10,700	4,033	3,914	3,053	10,741	5,230	1,612	2,176	9,606	3,658	680	927	4,505	1,893	163
Net Peak Load (Peak Load - BTM) (MW)	2,090	10,584	4,033	3,874	2,997	10,266	5,230	1,611	2,164	9,447	3,494	637	927	4,470	1,782	162



# Wind and Solar Summary in WECC 2032

Data Resource	Wind Capacity (MW)	Solar Capacity (MW)
2022 capacity (WECC 2022 State of Interconnection Report)	29,000	30,000
GridView database for WECC 2030 (v. 2.3)	35,723	39,908
GridView database for WECC 2032 (v. 2.1)	45,092	62,403

## Summary at the BA level:

Types of installed capacity	AESO	AVA	AZPS	BANC	BCHA	BPAT	CAISO	CFE	CHPD	DOPD	EPE	GCPD	IID	IPCO	LDWP	NEVP
Wind (MW)	5,240	119	624	0	761	5,378	11,102	40	0	0	0	0	0	718	420	149
SolarPV-Tracking (MW)	1,069	0	870	254	17	791	5,980	0	0	200	1,222	0	134	1,285	410	5,114
SolarPV-NonTracking (MW)	350	29	2,025	112	15	234	21,416	46	0	0	5	0	349	116	2,000	785
SolarCSP0 (MW)	0	0	0	0	0	0	275	0	0	0	0	0	0	0	0	0
SolarCSP6 (MW)	0	0	250	0	0	0	642	0	0	0	0	0	0	0	0	190
BTM (MW)	456	16	2,888	915	0	118	17,912	0	1	1	332	1	109	51	800	1,330
Peak Load (MW)	12,622	2,290	9,016	5,016	12,763	10,049	51,469	4,864	513	529	2,538	1,409	1,319	4,900	7,037	8,849
Net Peak Load (Peak Load - BTM) (MW)	12,622	2,289	8,534	4,672	12,763	10,046	45,684	4,864	513	529	2,438	1,408	1,276	4,889	6,832	8,695


  

Types of installed capacity	NWMT	PACE	PACW	PGE	PNM	PSCO	PSEI	SCL	SRP	TEPC	TIDC	TPWR	WACM	WALC	WAUW
Wind (MW)	847	6,561	2,248	766	2,978	4,697	658	0	0	437	0	0	748	485	0
SolarPV-Tracking (MW)	0	3,097	167	0	1,906	1,842	0	0	2,241	418	0	0	134	682	0
SolarPV-NonTracking (MW)	177	1,625	1,306	149	154	699	2	0	1,110	150	120	0	4	8	0
SolarCSP0 (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SolarCSP6 (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BTM (MW)	21	627	255	85	409	1,720	346	63	264	341	74	9	25	52	1
Peak Load (MW)	2,121	11,331	4,116	4,331	3,262	11,006	5,395	1,777	10,543	4,136	756	868	4,687	1,887	188
Net Peak Load (Peak Load - BTM) (MW)	2,108	10,947	4,114	4,301	3,113	10,374	5,395	1,777	10,422	4,022	731	868	4,664	1,850	188

# CAISO 2032 Reserve Results


- January Load Following
- July Load Following
- January Regulation
- July Regulation

# CAISO January 2032 Load Following decomposed (95% case) (LF capacity needs by each individual resource)



Note: the total requirement (dark blue in the graph) is not a simple linear addition of individual components


# CAISO July 2032 Load Following decomposed (LF capacity needs by each individual resource)



Note: the total requirement (dark blue in the graph) is not a simple linear addition of individual components


# CAISO July 2032 Load Following decomposed

(Percent of each resource of total LF capacity)






# CAISO January 2032 Regulation decomposed (95% case) (RL capacity needs by each individual resource)



Note: the total requirement (dark blue in the graph) is not a simple linear addition of individual components

# CAISO July 2032 Regulation decomposed (RL capacity needs by each individual resource)



Note: the total requirement (dark blue in the graph) is not a simple linear addition of individual components

# CAISO July 2032 Regulation decomposed

(Percent of each resource of total Reg capacity)

