


Two Broken Conductor Events


**Presented by: Joe Livingston P.E.
Great River Energy**

GRE transmission system




- 27 member-owner cooperatives
- 5,100 miles transmission
- 677 miles of transmission line maintained for others
- 109 transmission substations
- 1574 Relays


Event 1: SHERCO-Benton Co. 345 kV Line




~22:31:54 A-Phase Bus work breaks open



Broken A-Phase buswork at Benton Co




22:31:54.836 Bus work contacts ground




Benton Co Primary relay ER


22:31:54.836 Benton County:
 Sherco primary 345kV Line relay
 (SEL-411L) & secondary relay
 (SEL-421) correctly detected an
 A-G fault (**67G1**, 51S01) and
 correctly tripped breakers RB5
 and RB6 (**OUT201**, IN201-52a,
OUT203, IN301-52a). Correctly
 initiated BFI for RB5 & 6
 (**OUT301**, **OUT304**); and initiated
 RCI for RB5 & 6 (OUT302).



22:31:54.836 only Benton County trips




~22:31:56 TR9 tertiary over-current operates




Sherco DFR

1. A-Phase breaks between CCVT & Transformers
2. Benton Co. Relays detects A-G fault but don't transmit PT
3. Benton Co. TR9 51T trips LOR, which TT Sherco breakers




Event 2


Event 2: Dickinson-St Boni. 115 kV Line



Approximately 23:57:33



23:57:34.05 A-Phase contacts ground




23:57:34.05 Relay Events


► Dickinson




► St. Boni.



23:57:34.404 Dickinson relays trip




23:57:34.641 WB2/86BF trips (12 cycle)




23:57:34.641 Dickinson BF Relay Event

- Current continues to flow on A-Phase after WB1 trips
- Voltage is still on A-Phase
- trips WB2/86BF (OUT104)
- WB2 remains closed (IN101)




23:57:34.715 St Boni Relay Event


- After WB2/86BF trips WB1 and TT Lake Pulaski current reduces from St. Boni
- Ground over-current (51S1) drops out
- PT & TT never received at St Boni since A-Phase open




Approx. 23:57:35 WB2 finally trips (1 sec)



1:54 A.M. ~2-Hours later Lineman arrive




1:55 A.M. Line is de-energized




9:41 A.M. Line is repaired and put back in service

<Public>



Corrective Action Plan

- Add broken conductor logic
- Add Directional Ground Over-current in permission trip to assist in detecting high-impedance fault



$$d = \frac{1}{2}gt^2 \rightarrow t = \sqrt{\frac{2d}{g}}$$

$$t = \sqrt{\frac{2(30)}{32.2}}$$

time ≈ 1.37 s

Broken Conductor Logic

<Public>

Quantities Data Table




| Cursor | Color | Name | Real | Imag | Mag | Ang |
|---------|--------|------------------|-------------|--------------|------------|---------------|
| Orange | Orange | ZERO_SETTING_BKD | -0.9969952 | 0.0029073278 | 0.99699944 | 179.83293 Deg |
| Magenta | Orange | ZERO_SETTING_BKD | -0.99698704 | 0.0029151118 | 0.99699134 | 179.83247 Deg |

Filter Rows by Cursor

☐ Orange Cursor ☐ Magenta Cursor ☒ Both Cursors

Chart Options

Advanced Options




Broken Conductor Logic

Pros:


1. Both terminals would trip prior to fault occurring in both events 1 and 2
2. Auto-Reclosing would be canceled
3. Alarm System Operations

Cons:


1. Fault distance would be unknown *



Causes of wildfire ignition related to the power system



GRE conductor down



***2024: January-August**

Note: Some broken-conductor is operated by GRE but not owned and/or protected by GRE.

Transmission Line Relays

- 765 Line Relays
- 183 SEL-400 series
 - 44 SEL-411L
 - 138 SEL-421
 - 1 SEL-T401L
- 57 GE
 - 40 D60
 - 17 D90
- 45 ERLPhase
 - 45 L-PRO
- 480 SEL-300 series or older
 - 196 SEL-311B
 - 257 SEL-311C
 - 9 SEL-311L
 - 18 SEL-321

Broken Conductor Detection

Can be detected:

- Radial line
- 2-terminal lines
- 3-terminal lines with piloting
- Up to the point of the first tap

Cannot be detected:

- 3-terminal line without piloting (only terminal w/ broken conductor can be detected)
- Beyond the first tap point

Detectable Broken Conductor

| BES | miles of line with detectable broken conductor | undetectable broken conductor | % of line length of detectable broken conductor logic |
|---|--|-------------------------------|---|
| 2-Terminal Lines protection wholly owned by GRE | 469 | 25 | 95% |
| 2-Terminal Lines protection not wholly owned by GRE | 1342 | 96 | 93% |
| 3-Terminal Lines protection not wholly owned by GRE | 153 | 275 | 36% |
| BES Line totals | 1,964 | 396 | 83% |

Detectable Broken Conductor

| Subtransmission (34.5, 41.6, 46, and 69 kV) | miles of line with detectable broken conductor | undetectable broken conductor | % of line length of detectable broken conductor logic |
|---|--|-------------------------------|---|
| 2-Terminal Lines protection wholly owned by GRE | 830 | 644 | 56% |
| 2-Terminal Lines protection not wholly owned by GRE | 274 | 400 | 41% |
| 3-Terminal Lines protection wholly owned by GRE | 145 | 69 | 68% |
| 3-Terminal Lines protection not wholly owned by GRE | 42 | 178 | 19% |
| Radial lines | 1134 | 0 | 100% |
| Subtransmission Line totals | 2,425 | 1,291 | 65% |

Detectable Broken Conductor

| | miles of line with detectable broken conductor | undetectable broken conductor | % of line length of detectable broken conductor logic |
|--------------|--|----------------------------------|---|
| Total System | 4,389 | 1,687 | 72% |

References

1. Zero-Setting Broken Conductor Detection Method Using Local Measurements Only

Yangfeng Gong, Gandhali Juvekar, and Kanchanrao Dase, Schweitzer Engineering Laboratories, Inc.

Questions?

