



PCDS Meeting


April 30, 2025

WECC

ADS Schedule

- Review Case
 - May 7-21, 2025
 - Review/Changes
 - May 21-28, 2025
 - Approve Case
 - May 28, 2025
- * Cancel the May 14th PCDS meeting

Hydro Proportional Load Following



Hydro Proportional Load Following

- Active Hydro units
 - Monthly Total Units = 34
 - Weekly Total Units = 30

Generator Placement Methodology

Methodology

- Unmapped Generators in PCM to PF
 1. Latitude/Longitude ~ 700 generators
 1. ~ 450 unmapped generators from PF with coordinates
 2. County and State ~ 50
 3. State and BA ~ 40
- * Bus Names – Generators with a Bus/Substation names ~ 140

Generator Placement Methodology

- “Close Enough” – distance range (10, 25, 50 miles?)
- Latitude/Longitude
 1. Unmapped PF generators with locations
 2. Bus locations in same BA
 - KV Limit – [APFTF](#) limited by highest KV in BA
- Closest bus to generator
 - KV Limit
 1. Closest bus to generator no KV Limit

Generator Placement Methodology

- County and State
 1. Use open PF with Generator Type/Fuel – no KV limit
 2. Use known bus locations
 3. Use bus within the BA
- State and BA
 1. Use open PF with Generator Type/Fuel
- Bus Name
 1. Match with existing Bus/Substation Name and KV

To Do

- To Do
 - Data Checks
 - Aggregations/Distribution Table check
 - 2005 AESO Hydro Data
 - Thermal heat rate update
 - Start review of the case
 - Update placed units from the LnR

Generator Placement Methodology

- KV Limit
 - Based on APFTF
 - Used ranges

Interconnection Voltage	Resource Capacity
0 to 34.5 kv	Up to 5 MW
34.5 to 69 kv	5 to 25 MW
115 kv	25 to 50 MW
230 kv	50 to 125 MW
500 kv	250 to 1250 MW

Interconnection Voltage	Resource Capacity
0 to 34.5 kv	Up to 5 MW
34.5 to 69 kv	5 to 25 MW
115 kv	25 to 50 MW
230 kv	50 to 125 MW
345 kv	125 to 250 MW
500 kv	Greater 250 MW



www.wecc.org