




A Bus Cleared and a Hidden Breaker Insulation Failure Revealed

Robert Roman and Kevin Damron
Avista Utilities

Emma Clawson
Schweitzer Engineering Laboratories, Inc.


Avista service territory

- Population of 1.7M
- Miles of transmission lines
 - 700 miles at 230 kV
 - 1,600 miles at 115 kV



Day of event – background

- Historically low lightning density occurred in area
- Substation did not have
 - Lightning arrestors on breakers
 - Shield wires on transmission lines




Lightning events per km² per year



Substation layout

- Substations of interest – Sub A, Sub B, and Sub C
- 230 kV bus and lines
- Sub A protection
 - High-impedance bus diff (87B1)
 - Percentage-restrained bus diff (87B2)
- Line protection
 - Distance
 - 87L




Event analysis

Event date – June 27, 2023


Initial information and assumptions

- Sub A–Sub B line and Sub A bus tripped at same time
- No damage was visible at Sub A
- Technicians reenergized Sub A




Sequence of Events – BG fault

Time	Event
16:37:00.5165	Sub A–Sub B line fault




Sequence of Events – Sub A–Sub B line trips

Time	Event
16:37:00.5165	Sub A–Sub B line fault
16:37:00.5270	Sub A–Sub B line relays trip



Sequence of Events – Sub A bus clears


Time	Event
16:37:00.5165	Sub A–Sub B line fault
16:37:00.5270	Sub A–Sub B line ~428 ms relays trip
16:37:00.9546	87B1 trips Sub A bus
16:37:00.9850	Bkr 1, Bkr 2, Bkr 4, Bkr 5 52As begin deasserting



Sequence of Events – Sub B recloses

Time	Event
16:37:00.5165	Sub A–Sub B line fault
16:37:00.5270	Sub A–Sub B line relays trip
16:37:00.9546	87B1 trips Sub A bus
16:37:00.9850	Bkr 1, Bkr 2, Bkr 4, Bkr 5 52As begin deasserting
16:37:01.6553	Sub B Bkr 7 recloses


~1 s



Sequence of Events – Sub A bus clears again


Time	Event
16:37:00.5165	Sub A–Sub B line fault
16:37:00.5270	Sub A–Sub B line relays trip
16:37:00.9546	87B1 trips Sub A bus
16:37:00.9850	Bkr 1, Bkr 2, Bkr 4, Bkr 5 52As begin deasserting
16:37:01.6553	Sub B Bkr 7 recloses
17:05:21.2273	87B2 attempts to trip Sub A bus

~28 min




Sequence of Events – Sub C Bkr 6 trips

Time	Event
16:37:00.5165	Sub A–Sub B line fault
16:37:00.5270	Sub A–Sub B line relays trip
16:37:00.9546	87B1 trips Sub A bus
16:37:00.9850	Bkr 1, Bkr 2, Bkr 4, Bkr 5 52As begin deasserting
16:37:01.6553	Sub B Bkr 7 recloses
17:05:21.2273	87B2 attempts to trip Sub A bus
17:05:21	Sub C Bkr 6 trips





Sequence of Events – Sub C Bkr 6 recloses



Time	Event
16:37:00.5165	Sub A–Sub B line fault
16:37:00.5270	Sub A–Sub B line relays trip
16:37:00.9546	87B1 trips Sub A bus
16:37:00.9850	Bkr 1, Bkr 2, Bkr 4, Bkr 5 52As begin deasserting
16:37:01.6553	Sub B Bkr 7 recloses
17:05:21.2273	87B2 attempts to trip Sub A bus
17:05:21	Sub C Bkr 6 trips
17:05:22	Sub C Bkr 6 recloses





Initial BG fault on Sub A–Sub B line





Initial BG fault on Sub A–Sub B line





High-impedance bus differential relay trips Sub A bus





Percentage-restrained differential relay analysis




Percentage-restrained differential relay analysis – Bkr 3 currents




Is current flowing through open Bkr 3?




Is current flowing through open Bkr 3?



Is current flowing through open Bkr 3?




Is current flowing through open Bkr 3?





Lightning strike report

- Initial BG fault 16:37:00.5165
- 5 high-frequency current transients 16:37:00.946 to 16:37:01.400





Lightning strike time	Approximate distance from Sub A (mi)	Approximate distance from line (ft)	
16:37:00	0.625	NA	
16:37:00	0.606	341	1
16:37:00	0.890	156	2
16:37:00	0.890	65	3
16:37:00	0.890	40	4
16:37:00	1.004	0	5
16:37:00	0.871	176	6
16:37:00	0.871	NA	
16:37:01	0.890	252	7
16:37:01	0.890	77	8



Percentage-restrained differential relay analysis



High-impedance bus differential relay trips Sub A bus




High-impedance bus differential relay trips Sub A bus




High-impedance bus differential relay trips Sub A bus

- Identify two unfiltered points
- Pass them through a half-cycle cosine filter at 16 samples per cycle (8 points), resulting in
 - 9 sample output at 16 samples per cycle
 - 5 sample output when downsampled to 8 samples per cycle




Sub B Bkr 7 recloses successfully



- 1 second after initial BG fault, Sub B Bkr 7 recloses
- Sub B supplies 42 A charging current
- Bkr 3 is able to withstand nominal voltage





Sub A tripped again by 87B2 relay




Percentage-restrained bus differential relay trip




Percentage-restrained bus differential relay trip




Is current flowing through open Bkr 2?



Is current flowing through open Bkr 2?



Is current flowing through open Bkr 2?



Lightning strike report

- First high-frequency current transient that initiated the fault was at 17:05:21.2128
- Second high-frequency current transient that occurred during fault was at 17:05:21.2371

Lightning strike time	Approximate distance from Sub A (mi)	Approximate distance from line (ft)
17:05:21	3.84	417
17:05:21	3.84	103
17:05:22	NA	NA

Event analysis conclusions


Three separate faults and relay responses

- Initial Sub A–Sub B line BG fault occurred
- Bkr 3 internal flashover (caused Sub A bus to be cleared)
- Bkr 2 internal flashover (fault occurred)

Breaker inspection results


Bkr 3

- Gas sample was normal
- No damage was visible



Bkr 2

- Gas sample indicated problem
- Arcing marks were visible
- Breaker sustained 1,062 A rms fault current



Bkr 2 damage



Lessons learned

- Preventative actions
 - Add shield wires
 - Add surge arrestors at 230 kV level
- Benefit of multiple operating principles
- Depth of event analysis
 - Low- and high-resolution relay event reports
 - Lightning strike reports

Questions?

