



WECC SRS

State Service Load ID SS

Kalin Lee

Bonneville Power Administration



Proposal

- Removed language from
WECC Data Preparation Manual (DPM)
“Load modeling generator station service must have
Load ID set to “SS.””

Background

- Bonneville Power Administration is updating our internal methodology for load IDs in order to avoid frequent load topology changes (additions, deletions)
- This will reduce workload and reduce errors
- The only WECC DPM item this relates to is “Load ID set to “SS”.”, but for BPA this is more significant

Model Data Management

- **Distinct Data Types**

1. Topology (Bus numbers, Circuits, IDs)
 - Foundational to the model
 - Errors are inherently significant
2. Parameters (Impedance, ratings, MW, etc.)
 - Mapped onto the topology
 - Easy to change

- **Recommend This Practice**

- For topology changes, change topology
- For parameter changes, only change parameters;
- Avoid changing the topology (when possible), in order to avoid workload and errors

Data Coordination

- Some data is clearly defined
- Other data, such as IDs, is NOT clearly defined
 - This is up to preferred practice
 - This data is sometimes negotiated between the Data Maintainer, Area Coordinator, and Data Owner

Redundant Requirement

- Station Service load is already labeled with Climate Zone “PPA_AUX” or similar
 - Alternatively, custom fields or user-defined fields or other labels could be applied to identify these, if preferred