


PCDS Meeting

Jon Jensen
WECC

Andrew Fay, Brandon Wilde, Anuj Patil
WECC



Updated Wind Shapes From PNNL





2036 ADS V1.0 Items

- V1.0 matching Power Flow
 - Posted
 - Documents → 2036 ADS Files → Version 1.0 → Matching Power Flow

Documents > 2036 ADS Files > Version 1.0 > Matching Pow...

[See all](#)

+ New ▾ ↑ Upload ▾ ☰ ▾ ⓘ

Name ▾	Modified ▾	Modified By ▾
CrossTie (Scenario)	4 minutes ago	bwilde@wecc.org
CRTP (Scenario)	5 minutes ago	bwilde@wecc.org
36HS1_Matching_withPCM_V1.epc	6 minutes ago	bwilde@wecc.org
36HS1_Matching_withPCM_V1.pwb	6 minutes ago	bwilde@wecc.org
36HS1_Matching_withPCM_V1.sav	About an hour ago	bwilde@wecc.org



2036 ADS V2.0 Items

- Big Eddy-Quenette Creek Rating
- Mercer Load- Non Conforming
- 2036 ADS_2PF – Only PF enabled
 - Out for review
- 2036 ADS_2LnR – Only LnR units enabled
 - Out for review
- CIPB Load clipping add 25 aMW
- Add Klamath – Should have been in PF (Dev Status “Other Added Projects”)
- Future meetings



Items in progress

- Generation placement feedback
- Case Cleanup
 - Double check L&R units are correctly represented
 - Duplicates
 - Congestion
 - Gen placement
 - Gen distributions
 - Gens status'
 - Hybrids
 - Ref Busses
 - Contracted units



Summary of “Add-on” Transmission/Gen Projects

- Cascade Renewable (CRTP): V1 and V2
 - Not included, but a scenario to add in
- CrossTie: V1 and V2
 - In case, default to status off. Scenario to turn on
- SWIP (N/S): V1 and V2
 - In case, default to status online
- TransWest Express: V1 and V2
 - In case, default to status online
- SunZia Gen (on Bus 15080): V1 and V2
 - In case, default to status online
- GERP 1.0 and 2.0 (f.k.a. Evolving Grid): V2
 - 1.0-In case, default to status online
 - 2.0-In case, default to status online
- VEA (Sloan and Trout Canyon): V1 and V2
 - In case, default to status online
- North Plains Connector (as a generator turned off): V2
 - In case, default to status off



2036 ADS PCM V2 (PF and LnR cases)


**Cases out for review
(posted on PCDS Team
Site)**



Peak Load

Peak Load by Area

CASENAME ● 2036_V2_LnR_Draft_05-15-2026 ● 2036_V2PFX_DRAFT_5-13-2026_Full_Year






Annual Energy


Generation by Fuel Type

Fuel Type ● Uranium ● Coal ● NaturalGas ● Bio ● Geothermal ● Other ● Water ● Sun ● Wind ● MWh



Generation by Fuel Type


Fuel Type ● Uranium ● Coal ● NaturalGas ● Bio ● Geothermal ● Other ● Water ● Sun ● Wind ● MWh






Regional Net Transfers

Regional Transfers*
Annual Net GWh
2036_V2_LnR_Draft_05-15-2026



Regional Transfers*
Annual Net GWh
2036_V2PFX_DRAFT_5-13-2026_Full_Year





Regional Net Transfers


CASENAME	INTERCHANGE	Flow (GWh)	FLOW	Max Flow (MW)	Min Flow (MW)	Positive Flow (GWh)	Positive Flow Hours (%)	Negative Flow (GWh)	Negative Flow Hours (%)
2036_V2_LnR_Draft_05-15-2026	AB_EAST	0 0 >>		0.0	0.0	0.0	100.0	0.0	0.0
2036_V2PFX_DRAFT_5-13-2026_Full_Year	AB_EAST	0 0 >>		0.0	0.0	0.0	100.0	0.0	0.0
2036_V2_LnR_Draft_05-15-2026	BC_AB	4686.3 4,686 >>		1,200.0	-1,000.0	5,304.3	77.9	618.0	22.1
2036_V2PFX_DRAFT_5-13-2026_Full_Year	BC_AB	-812.9 << 813		1,200.0	-1,000.0	1,981.5	38.2	2,794.4	61.8
2036_V2_LnR_Draft_05-15-2026	BS_NW	6414.6 6,415 >>		3,839.4	-2,536.6	9,725.6	68.1	3,311.0	31.9
2036_V2PFX_DRAFT_5-13-2026_Full_Year	BS_NW	8922.4 8,922 >>		3,789.3	-2,357.3	10,701.4	79.1	1,778.9	20.9
2036_V2_LnR_Draft_05-15-2026	BS_RM	1946.6 1,947 >>		2,353.7	-1,794.7	3,550.7	55.7	1,604.1	44.3
2036_V2PFX_DRAFT_5-13-2026_Full_Year	BS_RM	-2659.4 << 2,659		2,247.5	-2,058.0	1,563.6	29.6	4,223.1	70.4
2036_V2_LnR_Draft_05-15-2026	CA_BS	-24731 <<< 24,731		814.4	-5,537.3	48.9	3.9	24,779.9	96.1
2036_V2PFX_DRAFT_5-13-2026_Full_Year	CA_BS	-23318.1 <<< 23,318		1,400.0	-5,537.3	107.5	6.0	23,425.6	94.0
2036_V2_LnR_Draft_05-15-2026	CA_NW	-8965.2 << 8,965		4,461.2	-7,804.8	2,774.8	32.4	11,740.0	67.6
2036_V2PFX_DRAFT_5-13-2026_Full_Year	CA_NW	1642.3 1,642 >>		4,737.6	-5,701.4	7,152.5	56.3	5,510.2	43.7
2036_V2_LnR_Draft_05-15-2026	CA_SW	-12639.1 << 12,639		10,169.0	-12,105.4	7,823.9	34.5	20,463.0	65.5
2036_V2PFX_DRAFT_5-13-2026_Full_Year	CA_SW	-1194.5 << 1,195		12,232.6	-10,234.0	12,901.7	47.7	14,096.3	52.3
2036_V2_LnR_Draft_05-15-2026	NW_AB	1082.9 1,083 >>		313.5	-300.0	1,382.3	76.5	299.4	23.5
2036_V2PFX_DRAFT_5-13-2026_Full_Year	NW_AB	-701.2 << 701		313.5	-300.0	490.7	34.4	1,191.9	65.6
2036_V2_LnR_Draft_05-15-2026	NW_BC	-9614.1 << 9,614		1,470.2	-3,150.0	776.2	19.1	10,390.3	80.9
2036_V2PFX_DRAFT_5-13-2026_Full_Year	NW_BC	-12757.3 << 12,757		1,776.8	-3,150.0	468.9	11.2	13,226.2	88.8
2036_V2_LnR_Draft_05-15-2026	NW_EAST	737.8 738 >>		204.6	-143.1	812.8	84.0	75.0	16.0
2036_V2PFX_DRAFT_5-13-2026_Full_Year	NW_EAST	483.1 483 >>		55.0	55.0	483.1	100.0	0.0	0.0
2036_V2_LnR_Draft_05-15-2026	RM_EAST	-21.1 << 21		497.0	-476.7	265.8	42.2	286.9	57.8
2036_V2PFX_DRAFT_5-13-2026_Full_Year	RM_EAST	-21.1 << 21		497.0	-476.7	265.8	42.2	286.9	57.8
2036_V2_LnR_Draft_05-15-2026	RM_NW	1250.9 1,251 >>		285.0	-215.9	1,349.1	82.7	98.3	17.3
2036_V2PFX_DRAFT_5-13-2026_Full_Year	RM_NW	1604.3 1,604 >>		285.0	-231.4	1,663.3	88.9	59.1	11.1
2036_V2_LnR_Draft_05-15-2026	SW_BS	-5439.5 << 5,440		1,590.9	-2,487.3	822.8	21.8	6,262.3	78.2
2036_V2PFX_DRAFT_5-13-2026_Full_Year	SW_BS	-5867.6 << 5,868		1,245.6	-2,620.3	509.9	15.5	6,377.5	84.5
2036_V2_LnR_Draft_05-15-2026	SW_NW	277.3 277 >>		285.0	-285.0	883.4	56.0	606.1	44.0
2036_V2PFX_DRAFT_5-13-2026_Full_Year	SW_NW	-1457.6 << 1,458		285.0	-285.0	163.3	17.2	1,620.9	82.8
2036_V2_LnR_Draft_05-15-2026	SW_RM	-4149 << 4,149		882.6	-1,579.2	310.9	13.3	4,459.9	86.7
2036_V2PFX_DRAFT_5-13-2026_Full_Year	SW_RM	-4874.2 << 4,874		807.6	-1,484.3	153.6	7.9	5,027.8	92.1



Unserved Load


Unserved Load by Area

CASENAME ● 2036_V2_LnR_Draft_05-15-2026



Unserved Load by Month

CASENAME ● 2036_V2_LnR_Draft_05-15-2026






Dumped Energy


Dumped Energy by Sub Region

CASENAME ● 2036_V2_LnR_Draft_05-15-2026 ● 2036_V2PFX_DRAFT_5-13-2026_Full_Year



Dumped Energy

CASENAME ● 2036_V2_LnR_Draft_05-15-2026 ● 2036_V2PFX_DRAFT_5-13-2026_Full_Year







Paths


P45 SDG&E-CFE N-S

● MAX_LIMIT ● MIN_LIMIT ● FLOW



P45 SDG&E-CFE N-S

CASENAME ● 2036_V2_LnR_Draft_05-15-2026 ● 2036_V2PFX_DRAFT_5-13-2026_Full_...







Paths


P65 Pacific DC Intertie (PDCI) N-S

● MAX_LIMIT ● MIN_LIMIT ● FLOW



P65 Pacific DC Intertie (PDCI) N-S

CASENAME ● 2036_V2_LnR_Draft_05-15-2026 ● 2036_V2PFX_DRAFT_5-13-2026_Full_...






Paths


P66 COI N-S

● MAX_LIMIT ● MIN_LIMIT ● FLOW



P66 COI N-S

CASENAME ● 2036_V2_LnR_Draft_05-15-2026 ● 2036_V2PFX_DRAFT_5-13-2026_Full_...







Paths


COI_and_PDCI (N-S)

● MAX_LIMIT ● MIN_LIMIT ● FLOW



COI_and_PDCI (N-S)

CASENAME ● 2036_V2_LnR_Draft_05-15-2026 ● 2036_V2PFX_DRAFT_5-13-2026_Full...






Paths


P27 Intermountain Power Project DC Line NE-SW

● MAX_LIMIT ● MIN Jensen, Jon (jjensen@wecc.org) is signed in



P27 Intermountain Power Project DC Line NE-SW

CASENAME ● 2036_V2_LnR_Draft_05-15-2026 ● 2036_V2PFX_DRAFT_5-13-2026_Full...





Hybrids/Co-located Units

Hybrid/Co-located Modeling

- Hybrid: A co-located configuration where the paired generation and storage are managed as a single, integrated resource in the market. This allows for more flexible market participation, potentially higher capacity value, and unified dispatch control.
- Co-located: Two or more generation assets and/or storage are physically installed at the same site and share a single point of interconnection. They can operate as separate resources in the market, each with its own interconnection agreement and market participation path.

Hybrid/Co-located Modeling

- ADS Modeling approach
 - No matter if a unit has been designated as a hybrid or co-located. They will all be modeled as a two (or more) separate components.
 - The limit on the transformer or branch will be the Point of Interconnection limit (If provided in LnR) or the wind or solar Pmax.
 - All will be able to charge from grid or from the renewable resource.
 - Modeling in GridView using a Nomogram.



Nomogram Tables

NOMOGRAM_GENERAL							
Name	Monitored	Limit_UC	Limit_ED	Penalty_UC(\$/MWh)	Penalty_ED(\$/MWh)	Notes	LMPCalculationFlag
AntelopeHybrid	YES	639	639	6000	6000		#TRUE#

NOMOGRAM			
NomogramName	ItemTypeID	ItemName	ItemCoefficient
AntelopeHybrid	0	BS_CL_Antelope	1
AntelopeHybrid	0	Solar_CL_Antelope	1



Hybrid Example: EdSan 1 Edwards 1

SBPH6_PV

Bus: SBPH6_PV (29299)
Nom kV: 34.50
Area: SOCALIF (24)
Zone: SCE Windhub 230KV (253)

1.0000 pu
34.50 KV
-40.09 Deg
Not Valid \$/MWh

EdSan Edwards 1 (Battery)
Pmax: 50.43MW

0 MW
0 Mvar



34.999 MW
6.956 Mvar
Pmax: 40 MW



ID 1

0.00 MW
0.00 Mvar

Branch Options

Line	From Bus	To Bus	Circuit
Number	29988	29299	1
Name	SB_MD6_COL	SBPH6_PV	
Area Name	SOCALIF (24)	SOCALIF (24)	
Nominal kV	34.50	34.50	

Labels ... no labels

Display Parameters Fault Info Owner, Area, Zone, Sub Custom Stability Geography

Status
 Open
 Closed

Branch Device Type
 Allow Consolidation
 Has Line Shunts

Length 0.00

Calculate Impedances >

Normal Status
 Open
 Closed

Per Unit Impedance Parameters

Series Resistance (R)	0.004430
Series Reactance (X)	0.006890
Shunt Charging (B)	0.005514
Shunt Conductance (G)	0.000000

MVA Limits


Limit A	44.600
Limit B	44.600
Limit C	44.600
Limit D	44.600
Limit E	44.600
Limit F	44.600
Limit G	44.600
Limit H	44.600
Limit I	0.000
Limit J	0.000
Limit K	0.000

Convert Line to Transformer Exchange From and To Buses

D-FACTS Devices on the Line Has D-FACTS


OK Save Save to Aux Delete Cancel Help

35.0 MW
7.0 Mvar
35.7 MVA



Transformer Limit: 44.6 MVA

CKT 1






EIA Projects

2026 Jan EIA860M Under Construction Projects Review

- Reviewed the Under Construction projects (TS, U and V statuses) from the Planned inventory of the EIA860M from Jan 2026.
- On comparing with the 2026 L&R Resource list, a total of 98 projects could not be mapped from the EIA Under Construction projects list to the L&R resource list.
- Majority of these unmapped projects from the EIA list were solar and battery units, primarily in the CISO and the Rocky Mountain/Southwest regions.
- These might align/map with the 'Generic' or IRP projects in the 2026 L&R resource list.
- Just under half of these projects have a capacity of less than 5 MW (total of 93 MW).


Total no. of Unmapped Under Construction Projects by Area

Area	Total projects by area
AVA	0
AZPS	6
BANC	2
BPAT	1
CHPD	0
CISO	56
EPE	1
GCPD	1
IID	0
LDWP	1
NEVP	1
NWMT	1
PACE	6
PACW	1
PGE	0
PNM	8
PSCO	9
PSEI	0
SRP	2
TEPC	1
WACM	1
WALC	0




MW Capacity of Unmapped Under Construction Projects by Area

Area	Total MW by area
AVA	0
AZPS	767
BANC	300
BPAT	25
CHPD	0
CISO	2704
EPE	130
GCPD	130
IID	0
LDWP	2
NEVP	113
NWMT	80
PACE	14
PACW	2
PGE	0
PNM	375
PSCO	636
PSEI	0
SRP	170
TEPC	200
WACM	5
WALC	0




Share of the Unmapped Capacity by Subtype

Share of the unmapped MW capacity from the EIA860M Planned list by subtype



Share of the Statuses


- TS – Construction complete, but not yet in commercial operation
- U – Under construction, less than or equal to 50 percent complete
- V - Under construction, more than 50 percent complete



Share of the Statuses by MW Capacity

- TS – Construction complete, but not yet in commercial operation
- U – Under construction, less than or equal to 50 percent complete
- V - Under construction, more than 50 percent complete

Share of the statuses of the unmapped projects (MW capacity) from the EIA 860M





ENGAGE WITH WECC





engage@wecc.org



www.wecc.org | 801-582-0353



155 N 400 W, Salt Lake City, Utah 84103, USA