

Introduction

- 1. Title:** **Digital Circuits Synchronization**
- 2. Number:** COM-001-WECC-CRT-3
- 3. Purpose:** To minimize digital circuit timing problems between WECC entities owning or operating digital Time Division Multiplex (TDM) telecommunication networks. Timing circuit problems will be minimized by establishing synchronization requirements for the WECC telecommunication networks.
- 4. Applicability:**
 - 4.1. Functional Entities:**
 - 4.1.1.** Transmission Operator that owns or operates TDM telecommunication systems.
 - 4.1.2.** Transmission Owner that owns or operates TDM telecommunication systems.
- 5. Effective Date:** June 15, 2021

Requirements and Measures

WR1. Each Transmission Owner and each Transmission Operator shall employ at least one global positioning system (GPS) referenced clock or one autonomous referenced (e.g., cesium beam) primary reference source (PRS) clock, having a long-term accuracy of $+1 \times 10^{-11}$ with a slip rate of 1 slip per 72 days (stratum 1).

WM1. Each Transmission Owner and each Transmission Operator will have evidence showing the existence and use of at least one PRS within a telecommunication network as required in WR1.

WR2. Each Transmission Owner and each Transmission Operator's telecommunications network shall have built-in timing redundancies such that loss of a PRS reference signal does not result in loss of stratum 1 timing traceability to network elements.

WM2. Each Transmission Owner and each Transmission Operator will have evidence that its telecommunication networks have built-in timing redundancies such that loss of a reference signal does not result in a loss in stratum 1 timing traceability to network elements as required in WR2.

Acceptable evidence of timing redundancies may include, but is not limited to:

- Diagrams or drawings showing how timing signals propagate within the network(s);
- Screenshots of network management monitoring systems showing network timing signal propagation or routes;
- Diagrams, drawings, or screenshots of individual equipment configuration indicating capability to use multiple timing signals traceable to stratum 1.

WR3. Each Transmission Owner and Transmission Operator's telecommunications network shall have each of the following capabilities in responding to system or clock failures:

- 3.1.** Telecommunication equipment set to automatically reconfigure timing reference sources such that traceability to stratum 1 PRS is maintained.
- 3.2.** PRS clock failures, including loss of a GPS signal source, alarmed, and monitored.
- 3.3.** Synchronous optical networking (SONET) elements that indicate loss of stratum 1 traceability due to PRS failures.

WM3. Each Transmission Owner and each Transmission Operator will have evidence that its telecommunication networks have each of the capabilities listed in WR3, as required in WR3.



WR4. Each Transmission Owner and each Transmission Operator shall employ synchronization planning to reflect each of the following:

- 4.1.** Timing for each node in a telecom network is traceable to a PRS clock per WR1.
- 4.2.** Clocks with less than stratum 1 accuracy shall not be used except in emergency situations.
- 4.3.** The plan is reviewed and updated every 12 months.

WM4. Each Transmission Owner and each Transmission Operator will have evidence that it employed synchronous planning including each of the elements described in WR4.

Version History

Version	Date	Action	Change Tracking
1	March 3, 2011	Operating Committee Approval	Developed as WECC-0066. Initial Version
1	June 22, 2011	WECC Board of Directors Approved	Final
1	September 5, 2012	WECC Board of Directors changed designation from “CRT” to “RBP.”	Designation change
1	June 25, 2014	WECC Board of Directors changed designation from “RBP” to “CRT.”	Designation change
1	April 1, 2016	No change	Converted to new template
2	December 6, 2016	WECC Standards Committee approved the review and deemed the project complete.	<p>WECC-0112, Version 2 was developed to meet the mandatory five-year review of this WECC Criterion.</p> <p>WECC-0122 confirmed no substantive changes were required.</p> <p>Non-substantive changes were made to the Measures. Lower case was used where a defined term was not warranted.</p>
2.1	June 18, 2019	Errata	<p>Converted to newest template.</p> <p>In Version 2.1: 1) syntax was corrected, 2) “AKA” was deleted (WR3.3.3), 3) “but are not limited to” was corrected to “but is not limited to” (WM2) and, 4) Version History syntax was corrected.</p>
3	June 15, 2021	WECC Standards Committee	This document was reviewed as part of a five-year review. No substantive changes were made. The following non-substantive changes were made: 1) “...as required in WR4” was removed from WM4, and 2) the date for Attachment A, WECC TELWG Guideline, Digital Circuits Synchronization was updated from March 2010 to June 2019.

WECC receives data used in its analyses from a wide variety of sources. WECC strives to source its data from reliable entities and undertakes reasonable efforts to validate the accuracy of the data used. WECC believes the data contained herein and used in its analyses is accurate and reliable. However, WECC disclaims any and all representations, guarantees, warranties, and liability for the information contained herein and any use thereof. Persons who use and rely on the information contained herein do so at their own risk.



Attachments

Attachment A—References

WECC TELWG Guideline, *Digital Circuits Synchronization*, June 2019.

Rationale

A Rationale section is optional. If Rationale Boxes were used during the development of this project, the content of those boxes appears below.

Rationale Boxes were not developed for this project.