

Standard IRO-002-2 — Reliability Coordination — Facilities

A. Introduction

1. **Title:** Reliability Coordination — Facilities
2. **Number:** IRO 002-2
3. **Purpose:** Reliability Coordinators need information, tools and other capabilities to perform their responsibilities.
4. **Applicability**
 - 4.1. Reliability Coordinators.
5. ***Proposed Effective Date:**

In those jurisdictions where no regulatory approval is required, the standard shall become effective on the latter of either April 1, 2009 or the first day of the first calendar quarter, three months after Board of Trustee adoption.

In those jurisdictions where regulatory approval is required, the standard shall become effective on the latter of either April 1, 2009 or the first day of the first calendar quarter, three months after applicable regulatory approval.

B. Requirements

- R1. Each Reliability Coordinator shall have adequate communications facilities (voice and data links) to appropriate entities within its Reliability Coordinator Area. These communications facilities shall be staffed and available to act in addressing a real-time emergency condition.
- R2. Each Reliability Coordinator — or its Transmission Operators and Balancing Authorities — shall provide, or arrange provisions for, data exchange to other Reliability Coordinators or Transmission Operators and Balancing Authorities via a secure network.
- R3. Each Reliability Coordinator shall have multi-directional communications capabilities with its Transmission Operators and Balancing Authorities, and with neighboring Reliability Coordinators, for both voice and data exchange as required to meet reliability needs of the Interconnection.
- R4. Each Reliability Coordinator shall have detailed real-time monitoring capability of its Reliability Coordinator Area and sufficient monitoring capability of its surrounding Reliability Coordinator Areas to ensure that potential or actual System Operating Limit or Interconnection Reliability Operating Limit violations are identified. Each Reliability Coordinator shall have monitoring systems that provide information that can be easily understood and interpreted by the Reliability Coordinator's operating personnel, giving particular emphasis to alarm management and awareness systems, automated data transfers, and synchronized information systems, over a redundant and highly reliable infrastructure.
- R5. Each Reliability Coordinator shall monitor Bulk Electric System elements (generators, transmission lines, buses, transformers, breakers, etc.) that could result in SOL or IROL violations within its Reliability Coordinator Area. Each Reliability Coordinator shall monitor

***Mandatory BC effective date: April 15, 2013 per BCUC Order R-1-13**

Standard IRO-002-2 — Reliability Coordination — Facilities

both real and reactive power system flows, and operating reserves, and the status of Bulk Electric System elements that are or could be critical to SOLs and IROLs and system restoration requirements within its Reliability Coordinator Area.

- R6.** Each Reliability Coordinator shall have adequate analysis tools such as state estimation, pre- and post-contingency analysis capabilities (thermal, stability, and voltage), and wide-area overview displays.
- R7.** Each Reliability Coordinator shall continuously monitor its Reliability Coordinator Area. Each Reliability Coordinator shall have provisions for backup facilities that shall be exercised if the main monitoring system is unavailable. Each Reliability Coordinator shall ensure SOL and IROL monitoring and derivations continue if the main monitoring system is unavailable.
- R8.** Each Reliability Coordinator shall control its Reliability Coordinator analysis tools, including approvals for planned maintenance. Each Reliability Coordinator shall have procedures in place to mitigate the effects of analysis tool outages.

C. Measures

- M1.** Each Reliability Coordinator shall have and provide upon request evidence that could include, but is not limited to, a document that lists its voice communications facilities with Transmission Operators, Balancing Authorities and Generator Operators within its Reliability Coordinator Area and with neighboring Reliability Coordinators, that will be used to confirm that it has communication facilities in accordance with Requirements 1 and 3.
- M2.** Each Reliability Coordinator shall have and provide upon request evidence that could include, but is not limited to, a data-link facility description document, computer print-out, training-document, or other equivalent evidence that will be used to confirm that it has data links with entities within its Reliability Coordinator Area and with neighboring Reliability Coordinators, as specified in Requirements 1 and 3.
- M3.** Each Reliability Coordinator shall have and provide upon request evidence that could include, but is not limited to, Energy Management System description documents, computer printouts, SCADA data collection system communications performance or equivalent evidence to demonstrate that it has real-time monitoring capability of its Reliability Coordinator Area and monitoring capability of its surrounding Reliability Coordinator Areas to identify potential or actual System Operating Limit or Interconnection Reliability Operating Limit violations.
- M4.** Each Reliability Coordinator shall have and provide upon request evidence that could include, but is not limited to, documentation from suppliers, operating and planning staff training documents, examples of studies, or other equivalent evidence to show that it has analysis tools in accordance with Requirement 6.
- M5.** Each Reliability Coordinator shall provide evidence such as equipment specifications, operating procedures, staff records of their involvement in training, or other equivalent evidence to show that it has a backup monitoring facility that can be used to identify and monitor SOLs and IROLs. (Requirement 7)

Standard IRO-002-2 — Reliability Coordination — Facilities

- M6.** Each Reliability Coordinator shall have and provide upon request evidence that could include, but is not limited to, a documented procedure or equivalent evidence that will be used to confirm that the Reliability Coordinator has the authority to veto planned outages to analysis tools, including final approvals for planned maintenance as specified in Requirement 8 Part 1.
- M7.** Each Reliability Coordinator shall have and provide upon request its current procedures used to mitigate the effects of analysis tool outages as specified in Requirement 8 Part 2.

D. Compliance

1. Compliance Monitoring Process

1.1. Compliance Monitoring Responsibility

The British Columbia Utilities Commission

1.2. Compliance Monitoring and Reset Time Frame

One or more of the following methods will be used to assess compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

1.3. Data Retention

Each Reliability Coordinator shall have current in-force documents used to show compliance with Measures 1 through 7.

If an entity is found non-compliant the entity shall keep information related to the noncompliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

***Mandatory BC effective date: April 15, 2013 per BCUC Order R-1-13**

Standard IRO-002-2 — Reliability Coordination — Facilities

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

1.4. Additional Compliance Information

None.

Standard IRO-002-2 — Reliability Coordination — Facilities

2. Violation Severity Levels:

Requirement	Lower	Moderate	High	Severe
R1	The Reliability Coordinator has demonstrated communication facilities for both voice and data exist to all appropriate entities and that they are staffed and available but they are less than adequate.	The Reliability Coordinator has failed to demonstrate that is has: 1) Voice communication links with one appropriate entity or 2) Data links with one appropriate entity.	The Reliability Coordinator has failed to demonstrate that is has: 1) Voice communication links with two appropriate entities or 2) Data links with two appropriate entities.	The Reliability Coordinator has failed to demonstrate that is has: 1) Voice communication links with more than two appropriate entities or 2) Data links with more than two appropriate entities or 3) Communication facilities are not staffed or 4) Communication facilities are not ready.
R2	N/A	The Reliability Coordinator or designated Transmission Operator and Balancing Authority has failed to demonstrate it provided or arranged provision for the exchange of data with one of the other Reliability Coordinators or Transmission Operators and Balancing Authorities.	The Reliability Coordinator or designated Transmission Operator and Balancing Authority has failed to demonstrate it provided or arranged provision for the exchange of data with two of the other Reliability Coordinators or Transmission Operators and Balancing Authorities.	The Reliability Coordinator or designated Transmission Operator and Balancing Authority has failed to demonstrate it provided or arranged provision for the exchange of data with three of the other Reliability Coordinators or Transmission Operators and Balancing Authorities.

*Mandatory BC effective date: April 15, 2013 per BCUC Order R-1-13

Standard IRO-002-2 — Reliability Coordination — Facilities

Requirement	Lower	Moderate	High	Severe
R3	N/A	The Reliability Coordinator has failed to demonstrate multi-directional communication capabilities to one of the Transmission Operators and Balancing Authorities in its Reliability Coordinator Area and with neighboring Reliability Coordinators.	The Reliability Coordinator has failed to demonstrate multi-directional communication capabilities to two or more of the Transmission Operators and Balancing Authorities in its Reliability Coordinator Area and with neighboring Reliability Coordinators.	The Reliability Coordinator has failed to demonstrate multi-directional communication capabilities to all of the Transmission Operators and Balancing Authorities in its Reliability Coordinator Area and with all neighboring Reliability Coordinators.
R4	The Reliability Coordinator's monitoring systems provide information in a way that is not easily understood and interpreted by the Reliability Coordinator's operating personnel or particular emphasis was not given to alarm management and awareness systems, automated data transfers and synchronized information systems.	The Reliability Coordinator has failed to demonstrate that is has detailed real-time monitoring capabilities in its Reliability Coordinator Area and sufficient monitoring capabilities of its surrounding Reliability Coordinator Areas to ensure that one potential or actual SOL or IROL violation is not identified.	The Reliability Coordinator has failed to demonstrate that is has detailed real-time monitoring capabilities in its Reliability Coordinator Area and sufficient monitoring capabilities of its surrounding Reliability Coordinator Areas to ensure that two or more potential and actual SOL and IROL violations are not identified.	The Reliability Coordinator has failed to demonstrate that is has detailed real-time monitoring capabilities in its Reliability Coordinator Area and sufficient monitoring capabilities of its surrounding Reliability Coordinator Areas to ensure that all potential and actual SOL and IROL violations are identified.

*Mandatory BC effective date: April 15, 2013 per BCUC Order R-1-13

Standard IRO-002-2 — Reliability Coordination — Facilities

Requirement	Lower	Moderate	High	Severe
R5	<p>The Reliability Coordinator failed to monitor:</p> <p>1) the status, real power flow or reactive power flow of Bulk Electric System elements that could result in one SOL violations or</p> <p>2) or operating reserves for a small portion of the Reliability Authority Area.</p>	<p>The Reliability Coordinator failed to monitor:</p> <p>1) the status, real power flow or reactive power flow of Bulk Electric System elements critical to assessing one IROL or to system restoration,</p> <p>2) the status, real power flow or reactive power flow of Bulk Electric System elements that could result in multiple SOL violations, or</p> <p>3) operating reserves.</p>	<p>The Reliability Coordinator failed to monitor:</p> <p>1) the status, real power flow or reactive power flow of Bulk Electric System elements critical to assessing two or more IROLs; or one IROL and to system restoration,</p> <p>2) the status, real power flow or reactive power flow of Bulk Electric System elements that could result in multiple SOL violations and operating reserves, or</p> <p>3) the status, real power flow or reactive power flow of Bulk Electric System elements critical to assessing one IROL or system restoration and operating reserves.</p>	<p>The Reliability Coordinator failed to monitor:</p> <p>1) the status, real power flow or reactive power flow of Bulk Electric System elements critical to assessing all IROLs and to system restoration, or</p> <p>2) the status, real power flow or reactive power flow of Bulk Electric System elements critical to assessing all SOL violations and operating reserves.</p>

*Mandatory BC effective date: April 15, 2013 per BCUC Order R-1-13

Standard IRO-002-2 — Reliability Coordination — Facilities

Requirement	Lower	Moderate	High	Severe
R6	The Reliability Coordinator failed to demonstrate that it has: 1) analysis tools capable of assessing all pre-contingency flows, 2) analysis tools capable of assessing all post-contingency flows, or 3) all necessary wide-area overview displays exist.	The Reliability Coordinator failed to demonstrate that it has: 1) analysis tools capable of assessing the majority of pre-contingency flows, 2) analysis tools capable of assessing the majority of post-contingency flows, or 3) the majority of necessary wide-area overview displays exist.	The Reliability Coordinator failed to demonstrate that it has: 1) analysis tools capable of assessing a minority of pre-contingency flows, 2) analysis tools capable of assessing a minority of post-contingency flows, or 3) a minority of necessary wide-area overview displays exist.	The Reliability Coordinator failed to demonstrate that it has: 1) analysis tools capable of assessing any pre-contingency flows, 2) analysis tools capable of assessing any post-contingency flows, or 3) any necessary wide-area overview displays exist.
R7	The Reliability Coordinator failed to demonstrate that: 1) it or a delegated entity monitored SOLs when the main monitoring system was unavailable or 2) it has provisions to monitor SOLs when the main monitoring system is not available.	The Reliability Coordinator failed to demonstrate that: 1) it or a delegated entity monitored one IROL when the main monitoring system was unavailable or 2) it has provisions to monitor one IROL when the main monitoring system is not available.	The Reliability Coordinator failed to demonstrate that: 1) it or a delegated entity monitored two or more IROLs when the main monitoring system was unavailable, 2) it or a delegated entity monitored SOLs and one IROL when the main monitoring system was unavailable 3) it has provisions to monitor two or more IROLs when the main monitoring system is not available, or	R9. The Reliability Coordinator failed to demonstrate that it continuously monitored its Reliability Authority Area.

*Mandatory BC effective date: April 15, 2013 per BCUC Order R-1-13

Standard IRO-002-2 — Reliability Coordination — Facilities

Requirement	Lower	Moderate	High	Severe
			4) it has provisions to monitor SOLs and one IROL when the main monitoring system was unavailable.	
R8	Reliability Coordinator has approval rights for planned maintenance outages of analysis tools but does not have approval rights for work on analysis tools that creates a greater risk of an unplanned outage of the tools.	Reliability Coordinator has approval rights for planned maintenance but does not have plans to mitigate the effects of outages of the analysis tools.	Reliability Coordinator has approval rights for planned maintenance but does not have plans to mitigate the effects of outages of the analysis tools and does not have approval rights for work on analysis tools that creates a greater risk of an unplanned outage of the tools.	Reliability Coordinator approval is not required for planned maintenance.

*Mandatory BC effective date: April 15, 2013 per BCUC Order R-1-13

Standard IRO-002-2 — Reliability Coordination — Facilities

E. Regional Variances

None identified.

Version History

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Revised
2		Deleted R2, M3 and associated compliance elements Replaced Levels of Non-compliance with the Feb 28, BOT approved Violation Severity Levels (VSLs) Corrected typographical errors in BOT approved version of VSLs	Revised
2	October 17, 2008	Adopted by NERC Board of Trustees	
2	March 17, 2011	Order issued by FERC approving IRO-002-2 (approval effective 5/23/11)	

***Mandatory BC effective date: April 15, 2013 per BCUC Order R-1-13**